

Project Name: Bilasuvar 445 MWac Solar PV Azerbaijan

Climate Change Risk Assessment Report



Document Information

Project Name	Bilasuvar 445 MWac Solar PV
Document Title	Climate Change Risk Assessment
Project Reference	2305/007
Client	Masdar Clean Energy
Project Manager	Barney Chesher
Project Director	Ken Wade

Document Control

Version	Date	Description	Author	Reviewer	Approver	
1.0	12/08/2024	Initial draft for Client comment	LBG	BC	МКВ	



Table of Contents

Table of Contents

Document Information
Fable of Contents 3
Abbreviations & Acronyms4
Key Terms & Definitions
L Introduction7
1.1 Project Background7
1.2 Objectives
2 Project Description8
2.1 Overview of Project Phases10
2.2 Project GHG Calculations
3 Legal & Institutional Framework13
3.1 National Laws & Regulations13
3.2 Requirements for Project Financing16
4 Climate Change Risk Assessment20
4.1 Approach & Methodology21
4.2 Baseline Climate Overview
4.3 Projected Climate Future and Physical Risks
4.4 Transition Risks
5 Appendix A - Hydrometeorological Study Prepared by JURU, 2024



Abbreviations & Acronyms

Acronym	Definition
ADB	Asian Development Bank
AEP	Annual Exceedance Probability
AIIB	Asian Infrastructure Investment Bank
ССКР	Climate Change Knowledge Portal
CCRA	Climate Change Risk Assessment
CMIP6	Coupled Model Inter-comparison Projects 6
COD	Commercial Operation Date
DFIs	Development Finance Institutions
DRM	direct rainfall method
E&S	Environmental and Social
EBRD	European Bank for Reconstruction and Development
EP	Equator Principles
EPAP	Equator Principle Action Plan
EPFIs	Equator Principles Financial Institutions
ESF	Environmental and Social Framework
ESIA	Environmental and Social Impact Assessment
ESMP	Environmental and Social Management Plan
ESMS	Environmental and Social Management System
ESP	Environmental and Social Policy
GHG	Greenhouse Gas
GW	Gigawatts
H&S	health and safety
IFC	International Finance Corporation
IFI	International Financial Institution
INDC	Intended Nationally Determined Contribution
IPCC	Intergovernmental Panel on Climate Change
LV	Low Voltage
Masdar	Abu Dhabi Future Energy Company
MENR	Ministry of Ecology and Natural Resources
MSL	mean sea level
MV	Medium Voltage
MW	Megawatt
NAMA	Nationally Appropriate Mitigation Actions
NAP	National Adaptation Plan
NDC	Nationally Determined Contributions
0&M	Operation and Maintenance
PMC	Project Management Company



Acronym	Definition
PPA	Power Purchase Agreements
PPE	Personal Protective Equipment
PRs	Performance Requirements
PSs	Performance Standards
PV	Photovoltaic
SCADA	Supervisory Control and Data Acquisition
SCS	Soil Conversation Service
SOCAR	State Oil Company of the Republic of Azerbaijan
SPEI	standardized precipitation evaporation index
SSPs	Shared Socioeconomic Pathways
TCFD	Task Force on Climate-Related Financial Disclosure
UNFCCC	United Nations Framework Convention on Climate Change
WBG	World Bank Group

Key Terms & Definitions

Developer (Masdar)	Is the developer of the Project before the establishment of the Project Company and is a shareholder in the Project Company. It oversees Environmental and Social (E&S)
,	performance and compliance.
The Project	Is incorporated for the development of the Project and is the owner of the Project
Company	and is the key entity that signed the loan agreement with the Lenders. Project
	Companies for this are Abu Dhabi Future Energy Company (Masdar) and State Oil
	Company of the Republic of Azerbaijan (SOCAR)
Project	PMC is appointed by the Project Company and is involved for the first two years of
Management	operation to ensure that the Operation and Maintenance (O&M) Contractor is
Company	adhering to the technical, environmental, and social project specifications required.
(PMC)	
Operation and	Is responsible for undertaking operation and maintenance activities of the whole
Maintenance	Project components and area during the operation phase of the Project. Main scope
(O&M)	includes: 1. Protection of investment and assets of the Project and optimizing its
Contractor	performance within established cost parameters by undertaking the operation
	activities as well as the maintenance works including preventive scheduled
	maintenance, and corrective unscheduled maintenance; 2. Optimizing labor
	enciency; 3. Enhancing asset performance; 4. Promoting awareness and
C. h	accountability, 5. Reducing downtime and failures, and 6. Improving safety.
Subcontractors	Subcontractors are identified as any entity (international or local) appointed directly
	and maintenance activities within the project area or provide a specific service for
	the project. This could include but not be limited to the following: civil checks and
	repairs, electrical and mechanical checks and repairs, replacing broken and damaged
	PV panels, water supply, waste collection, security services, etc. The subcontractors
	appointed include the following:
E&S	The E&S compliance obligations for this Project include:
Compliance	1. The national laws, regulations and standards
Obligations	



	2. At this stage, it is understood that Masdar is seeking an amount of project finance from financial Institutions (together "lenders"), potentially including commercial banks that are Equator Principles Financial Institutions (EPFIs) and Development Finance Institutions (DFIs). The lenders have their own internal environmental & social investment policies/standards by which the Project must align. These include:
	Asian Development Bank (ADB)
	Asian Infrastructure Investment Bank (AIIB)
	 European Bank for Reconstruction and Development (EBRD)
	 International Finance Corporation (IFC)
Project country	The Project is located in Bilasuvar district of Shirvan-Salyan region in Azerbaijan.
Project	Includes Azerbaijani and English.
Language	
Environmental	Is any central or local government department or statutory agency, body, authority
Statutory	or organization (including the Environment Agency) which has regulatory or
Authority	enforcement powers in relation to Environmental Law. In relation to this Project, the environmental statutory authority is Ministry of Ecology and Natural Resources (MENR)
Environmental	Any and all permits, licenses, approvals, registrations, notifications, exemptions and
Permit	other authorizations required under any Environmental Law which is required before
	any operation activities can commence onsite in relation to the Project. The
	environmental permit is referred to as permission for operation issued by MENR,
	Ministry of Health, and Ministry of Emergency Cases.
Local	Are the local communities, households, groups, and community leaders (including
communities	the village elders) that may be directly or indirectly affected by the Project and its
	activities. This includes people affected by social and/or environmental impacts
	autipulable to the Project.
	approximately 7 km from the partheastern side of the project site. The distance to
	the Bilasuvar district centre is approximately 16 km



1 Introduction

1.1 Project Background

Masdar signed implementation agreements with Azerbaijan's Ministry of Energy in June 2022 to develop a renewable energy program on a bilateral basis, with a total capacity of 10 gigawatts (GW) across multiple technologies.

Subsequently, Masdar signed joint development agreements with the State Oil Company of the Republic of Azerbaijan (SOCAR) for onshore wind and solar projects, and integrated offshore wind and green hydrogen projects, with a total combined capacity of 4 GW.

The Ministry of Energy of the Republic of Azerbaijan and Masdar signed an Implementation Agreement relating to the assessment, development, and implementation of a 4 GW_{ac} pipeline of solar photovoltaic (PV) and onshore wind projects in the Republic of Azerbaijan starting with 2 GW_{ac} as the first phase.

In June 2023, Masdar signed an agreement with the Ministry of Energy to design, finance, build and operate a 445 megawatt (MW) utility-scale solar farm project (the project). The Bilasuvar Solar PV Plant (the Project) is one of three projects making up the first phase and it is the focus of this report.

The Project is located in Bilasuvar district of Shirvan-Salyan region, Azerbaijan, approximately 140 km south of Baku. With a capacity of 445 MW. Once completed, the solar farm will displace 367,000 tons of carbon dioxide per year.

The Project will support Azerbaijan to:

- Reduce energy dependence on carbon-based fuels.
- Meet renewable energy targets.
- Reduce greenhouse gas emission rates.

Masdar has appointed 5 Capitals Environmental and Management Consulting (5 Capitals) to perform an Environmental and Social Impact Assessment (ESIA) for the Project. The ESIA will be developed following the requirements of the International Finance Corporation (IFC) Performance Standards (PSs) and with reference to EBRD Environmental and Social Policy 2019 (ESP 2019) Performance Requirements (PRs), Asian Development Bank (ADB) Safeguards, Asian Infrastructure Investment Bank (AIIB) Environmental and Social Framework, and the Equator Principles.

This document is the Climate Change Risk Assessment (CCRA) and has been prepared on behalf of Masdar. The purpose of this document is to present a climate change risk analysis following the requirements of the Equator Principles 4 2021 (EP4) for the Project. In line with that guidance, the scope of work is to include consideration of climate-related 'Physical Risks' as defined by the Task Force on Climate-Related Financial Disclosure (TCFD)2. This document will be submitted as part of Bilasuvar 445 MWac Solar PV Project ESIA package.



1.2 Objectives

This CCRA aims to identify the likelihood of future climate hazards and their potential impacts on the operation of the Project, Project workers and neighbouring communities. This is fundamental for informing the prioritization of climate action and adaption and resilience management requirements for the Project.

The CCRA aligns with the Lenders' requirements including Equator Principles Guidance Note on Climate Change Risk Assessment published in May 2023. The CCRA has been undertaken for the Project to calculate the Greenhouse Gas (GHG) emissions and assess of the physical and transition risks during the Project operation phase.

2 Project Description

The Project is located in Bilasuvar district of Shirvan-Salyan region, Azerbaijan, approximately 140 km south of Baku.



Figure 1 National Project Context

The administrative centre of Bilasuvar and the main residential settlements of district are located 11 km from the Project area, while the nearest settlements: Shorsulu, Dayikend and Sarvan communities are located to the north-east of the Project site at a distance of approximately 7 km. Adjacent to the Project, on its western boundary and separated by a canal, and in some locations a road, is the Lake Mahmudchala Important Bird Area.





Figure 2 Receptors Relative to the Project

The project will entail the development of a 445 MWac solar power project, within a fenced perimeter area of 1,454 ha. The project will not have a dedicated power line but will be integrated into the grid through a new substation in the Navahi settlement. The substation is essential for the prospective development of the network and is planned for construction irrespective of the Projects and is not solely tied to their integration. The development of the grid network within Azerbaijan is part of a Strategic Development Plan. Therefore, the development of the transmission line is not within the Project scope, nor does it fall under the definition of an associated facility.

Once developed, the project will be operational for a 30-year period.

The key project components include:

- PV Modules; the PV module considered for the plant will be bifacial monocrystalline modules.
- Inverters; the Project will have both central or string inverters options in the design and the inverter solution will be finalised during the detailed design phase of the Project.
- Mounting Structures; the Project will implement, single axis, E-W tracking, with a tracking range of -55° to +55° or better.
- Low Voltage (LV)/Medium Voltage (MV) Transformers; the Project is foreseen to set up the LV AC from Inverter up to 35 kV MV level.



- PV Plant substation including Power Transformer and Switchgears; the PV plant substation will be built within the PV plant and 35 kV will be stepped up to 300 kV through a power transformer.
- Civil Infrastructure (Roads, Fences, drainage as required, etc.)
- Other balance of plant such as cables, protection, Supervisory Control and Data Acquisition (SCADA) system etc.

2.1 Overview of Project Phases

This section presents the likely activities to take place during the Project development which will include three distinct phases: (i) construction, (ii) operation and (iii) decommissioning each of which is summarized below.

2.1.1 <u>Construction</u>

Construction Activities:

- Site preparation including fencing, clearing, levelling and grading;
- Establishment of access roads to the site;
- Installation of mechanical and electrical infrastructure for PV trackers, modules, and related equipment;
- Construction or compaction of internal roads on-site and other infrastructure including walkways & parking areas;
- Construction of storage facilities for equipment and materials, and construction of laydown area;
- Construction of general buildings, such as administrative building, sanitary rooms, workshops, electrical buildings, auxiliary buildings, and structures, etc.;
- Erection of security fencing;
- Excavation of cable trenches; and
- Construction of mechanical & electrical buildings including the SCADA building.
- Temporary construction facilities including temporary laydown areas, offices, workers accommodation and other facilities.

Construction Workforce

As an initial estimation, and based on experience on similar projects, the typical workforce during the peak construction period is estimated to be 700 – 1,500 workers for a solar PV plant of this size. The workforce will comprise a mix of highly qualified specialists, technicians and low-skilled personnel. Ideally, the low-skilled staff workforce will be encouraged to be sourced locally. Qualified specialists will be sourced both nationally and internationally, depending on the skills availability.



Equipment and Machinery

The following equipment and machinery are likely to be used to construct the Project:

- Excavators
- Graders
- Vibratory rollers
- Loaders
- Hydraulic driving machines
- Cranes and telescoping handlers; and
- Heavy goods vehicles and light good vehicles.

Utilities

<u>Water</u>: The anticipated maximum work force is around 1,000 at its peak and, with an average of 130 litres per person per day. At its peak workforce during construction there would be 130,000 litres/day required to cover the needs of the workforce (or 130 m³ per day).

<u>Power</u>: Power during the construction phase will be provided by diesel generators.

<u>Concrete and Cement</u>: Based on Masdar's Area 60 Solar PV project, which is located approximately 60 km north of the Project, it is expected that two potential cement manufacturers will be utilised during the construction phase, NORM Cement and Holcim Cement. Concrete producers may include SPARK Beton, Azkontakt Beton and Azital. All of these companies are capable of producing traditional and special types of the concretes required by large scale projects in the country.

Waste and Wastewater

Waste will be generated throughout the construction period. Waste streams will include excavation wastes, packaging wastes, domestic waste from construction workforce etc. Wastes will be segregated and stored onsite before being collected when required by a licensed waste management contractor to a licensed waste management facility.

Wastewater will be collected in septic tanks at site and removed periodically, when required, by a licensed wastewater contractor to a licensed wastewater management facility.

2.1.2 Operation and Maintenance

As per the Power Purchase Agreements (PPA), the plant is to be operational for 30 years. During the operational phase, maintenance will be conducted to ensure efficiency in energy production. Maintenance activities will include cleaning of panels, maintenance of electrical components and control equipment. The routine cleaning of the PV modules is to be conducted automatically by a dry-cleaning robot (i.e., brushes installed on tracks along the rows of the



modules) without the use of water in order to make the cleaning process more resource efficient (i.e., avoiding water use) and economically sound.

Operation Workforce

The number of people that are to be employed during operation is expected to be up to 50. A significant percentage is expected to be comprised of Azeris.

Utilities

<u>Water</u>: Water tanker trucks will transport water from outside the solar PV field to water storage tanks within the Project boundary to cover the water demand of the Project, as well as raw water for domestic use, firefighting water demand, and other non-potable water uses if required. Water will not be used for panel cleaning.

<u>Power</u>: Power during the operation phase will be supplied by connection to the national grid and use of Project-generated electricity.

Fuel: The Project will include an emergency diesel generator for use during black-out situations.

2.1.3 <u>Decommissioning</u>

Following the 30 operational years, the Ministry can decide whether to continue, upgrade or decommission; this is outside the scope of this study and to be decided at that time. Upgrading the PV power plant will entail either replacing old PV modules with new ones, augmenting the total peak power of the plant, or enhancing the plant's power by incorporating new elements.

In the event of decommissioning, the site will be restored close to its original condition, with a Decommissioning and Site Restoration Plan devised prior to this phase.

The components of a PV plant possess inherent value for either reuse or recycling, which will offset the costs of decommissioning the plant and restoring the site. Hazardous wastes will be disposed of in compliance with the environmental guidelines mandated by the country, while non-hazardous materials such as waste metals or plastics will be transported to designated recycling facilities, if available.

2.2 Project GHG Calculations

The project will be utilizing solar energy to produce electricity, which is a key positive impact regarding resource efficiency. The Project will have an installed capacity of 445 MW that will contribute to the national grid. This capacity will help meet the country's increasing electricity demand, as opposed to meeting such demands through conventional electricity production from thermal power plants.



Carbon emissions are categorized into three scopes, each representing different sources of emissions and levels of control:

- Scope 1: scope 1 emissions refer to direct emissions generated from sources owned or controlled by the entity.
- Scope 2: scope 2 emissions include indirect emissions associated with generation of purchased electricity, heat, or heat consumed by the entity. These emissions result from activities

The Project is expected to provide around 897 million kWhr of electricity annually. The Project will likely displace 367,000 million tons of CO₂ annually.

The construction phase of the Project will generate GHG emissions from on-site construction activities, including but not limited to transportation of materials, civil works and installation activities, processing of materials, fossil fuels burned in transporting and assembling the system, etc. The International Financial Institution (IFI), under the Framework for a Harmonized Approach to Greenhouse Gas (GHG) Accounting, published the "GHG Accounting for Grid Connected Renewable Energy Projects" (IFI, 2019). The document states that construction emissions for renewable energy projects may be excluded, where forms of renewable energy are generally acknowledged to have low construction/lifecycle emissions.

The operation phase figure covers all activities, including maintenance, cleaning of modules, replacing parts, etc. The power required during operation will be provided by the Project and therefore GHG emissions from power consumption are not anticipated.

Considering the above and based on the amount of GHG emissions displaced during operation as calculated above, GHG emissions from the Project are considered negligible.

3 Legal & Institutional Framework

This section presents the overall regulatory and policy framework applicable to the Project.

3.1 National Laws & Regulations

The Paris Agreement came into force on 4th November 2016. The Republic of Azerbaijan ratified the Paris Agreement on 9 January 2017.

The United Nations Development Programme in Azerbaijan and MENR signed a project on the Fourth National Communication and the Second Biennial Reporting under the United Nations Framework Convention on Climate Change (UNFCCC). The aim of the project is to support the Government of Azerbaijan through the MENR to continue reporting under the Convention. Climate change is reflected in the government's strategies as follows:

- Republic of Azerbaijan's Fourth National Communication to the UNFCCC (2021);
- Azerbaijan 2020: Look into the Future Development Concept (2014);



- Comprehensive Action Plan to improve environmental situation in the Republic of Azerbaijan in 2006 (2010);
- Action Plan on Improvement of the Ecological Situation and Efficient Use of Natural Resources in the Republic of Azerbaijan (2015–2020); and
- National Adaptation Plan (NAP).

Azerbaijan ratified the UNFCCC on January 10, 1995, and the Kyoto Protocol on July 18, 2000.

3.1.1 Intended Nationally Determined Contribution

The Intended Nationally Determined Contribution (INDC) represents a non-binding national strategy outlining climate change mitigation efforts in a country. It includes specific goals to reduce pollution1. INDCs connects a country's own rules with global efforts agreed upon in the Paris agreement. This aims to create a future that's better for the environment. These contributions are vital fighting climate change because they outline how much a country plans to cut down on pollution and emissions, following the guidelines of the United Framework Convention on Climate Change (UNFCCC).

The Republic of Azerbaijan actively participates in the implementation of the UNFCCC, the Kyoto Protocol and the Paris Agreement. In accordance with Article 4 of the Paris Agreement, the Republic of Azerbaijan has introduced its Nationally Determined Contributions (NDC) to the UNFCCC Secretariat in October 2015 and as a contribution to initiatives for preventing global climate change (mitigation initiatives) compared to 1990 (base year) aims to reduce greenhouse gas emissions by 35% by 2030. Azerbaijan's NDCs by 2050 were renewed in 2023. The new version of Azerbaijan's Nationally Determined Contributions by 2050 include the following₂:

- 1- **GHG emissions**: The Republic of Azerbaijan updated its NDC document in accordance with the Paris Agreement with a target of reducing its GHG emissions by 40% compared to 1990 levels by 2050, taking into account the maximum possible absorption capacity of forests and ecosystems.
- 2- **Energy Sector**: The Republic of Azerbaijan is accelerating renewable energy adoption through flexible tariff regulations, technical skill development, consumer awareness, and private sector involvement.
- 3- Heat Supply: The strategic roadmap for public utilities in Azerbaijan outlines specific indicators for installing modern, energy-efficient, and environmentally friendly boiler and heating systems in new and upgraded facilities. To enhance efficiency in the public utilities sector, several regulations have been approved. These measures aim to improve preventive actions and regulate relationships among manufacturers, suppliers, and consumers.

¹ What is an INDC? | World Resources Institute. (2015). Wri.org. https://www.wri.org/indc-definition 2 The Republic of Azerbaijan Updated document on Nationally Determined Contributions (NDC). (2023). https://unfccc.int/sites/default/files/NDC/2023-10/Second%20NDC_Azerbaijan_ENG_Final%20%281%29.pdf



- 4- Transport: Over the past decade, Azerbaijan has significantly developed its transportation system to become a key transit and trade hub, focusing on the restoration and construction of road and railway infrastructure along north-south and east-west corridors.
- 5- Industrial Processes and Product Use: Greenhouse gas emissions in Azerbaijan's industrial sector, notably from mining, chemical industry, metallurgy, and other manufacturing industries, increased by 2.5 times from 1990 to 2016, reaching 5.12% due to industrial growth, increased clinker production for cement since 2011, and methanol production starting in 2013. To mitigate these emissions, measures should be implemented to promote modern technologies, enhance energy efficiency, increase the use of alternative energy sources, and develop recycling initiatives in both public and private sectors.
- 6- Agriculture, Land Use, Land Use Change: The agricultural sector, the second-largest source of greenhouse gas emissions in Azerbaijan after the energy sector. The Strategic Roadmap for agricultural production and processing outlines preventive and adaptation policies to address climate change across four priority areas: developing mechanisms and adaptation plans to mitigate climate impacts, creating performance indicators for environmentally compliant agricultural production, assessing environmental impacts of land-use changes, and fostering environmentally friendly agricultural products.
- 7- Forestry: Azerbaijan prioritizes forest development due to their crucial role in greenhouse gas absorption. Forests, which are not typically used for industrial purposes, protect soil, regulate water, conserve biodiversity, shape microclimates, and absorb carbon. The State Program for Poverty Reduction and Sustainable Development aims to expand forested and protected areas, doubling greenhouse gas absorption to 7.2 million tons of CO2 equivalent by 2016 from 1990 levels. These efforts will enhance forest coverage and greenhouse gas absorption, supporting the country's updated Nationally Determined Contributions.
- 8- Waste Sector: Greenhouse gas emissions in Azerbaijan's waste sector have increased by 72% from 1990 to 2016, accounting for 2.2% of total emissions in 2016. Effective management of this sector is crucial for reducing emissions. The National Strategy for Improving Solid Waste Management outlines measures to enhance waste collection, promote recycling, reduce state subsidies, and boost the recycling market. Implementing this strategy aims to create favorable conditions for entrepreneurs and investors, establish new enterprises, increase employment, and incorporate international experience and modern technologies.

3.1.2 National Adaptation Plan

National Adaptation Plans (NAPs) were introduced at the UNFCCC COP16 in 2010 to help countries plan for climate adaptation. The NAP process is flexible building on existing adaptation efforts to integrate climate change considerations into national decision-making. With support from the United Nations countries globally are guided to create NAPs to identify medium- and long-term adaptations needs based on current climate science. The overarching



aim of NAPs is to systematic reduce climate-related damage, enhance adaptive capacity, and promote sustainable economic development by 2050.

As per the World Bank Group (WBG) and the Asian Development Bank (ADB) Climate Risk Country Profile published in 2021, Azerbaijan has committed to the Paris Climate Agreement, outlining its climate change mitigation strategies in the NDC submitted in 2017 and renewed in 2023. These strategies span several sectors, including energy, oil and gas, residential and commercial buildings, transport, agriculture, and waste management³. The country plans to align its climate change policies with EU standards, developing sector-specific guidelines for implementing the Paris Agreement, particularly in agriculture and energy. These initiatives mainly involve technological upgrades to minimize environmental impacts, alongside regulatory adjustments and public awareness campaigns³.

The National Adaptation Plan for Azarbaijan is not in place yet. In its Third National Communication to the UNFCCC in 2015, Azerbaijan identified adaptation measures in agriculture, water supply, forestry, coastal areas, human health, and tourism. The nation is in the process of developing a NAP, anticipated to be finalized by 2024. The NAP is expected to concentrate on water, agriculture, and coastal areas, as designated by the Ministry of Ecology³.

Additionally, Azerbaijan has created and executed Nationally Appropriate Mitigation Actions (NAMA) focusing on enhancing energy efficiency in buildings, modernizing the transport fleet with hybrid vehicles and promoting eco-driving, and capturing and utilizing associated gas in the oil industry. The initial NAMA projects, piloted with SOCAR (the State Oil Company), are being considered for broader implementation across the country₃.

3.2 Requirements for Project Financing

3.1.3 Equator Principles (Eps)

The Equator Principles is a voluntary set of principles institutions, called Equator Principles Financial Institutions (EPFIs), sign on to, in order to show their commitment to assess and manage the environmental and social risks of their projects. Equator Principles 4 (EP4) also sets out obligations for climate change risk analysis (CCRA) in line with the recommendations of the Task Force on Climate-related Financial Disclosures (TCFD). Following the EP4 guidance note on CCRA,7 a CCRA is required in the following instances:

- For Category A and, as appropriate, Category B projects. For these projects the CCRA is to include consideration of relevant climate-related 'Physical Risks' as defined by the Task Force on Climate-Related Financial Disclosure (TCFD).
- For all projects, in all locations, when combined Scope 1 (direct) and Scope 2 (indirect electricity) emissions are expected to be more than 100,000 (tCO2e) per year. For these projects the CCRA is to include consideration of climate-related 'Transition Risks' (as defined by the TCFD).

³ WBG & ADB. (2021). Climate Risk Country Profile: Azerbaijan (2021): The World Bank Group and Asian Development Bank. https://climateknowledgeportal.worldbank.org/sites/default/files/2021-06/15835-Azerbaijan%20Country%20Profile-WEB.pdf



Applicable and considered Equator Principles for the CCRA are listed in the table below:

Table 1 Summary of Equator Principles

No.	Principle	Discussions
1	Review &	Identifies categorization for projects as either Category A, B, or C. This is determined
	Categorization	by an E&S review and due diligence undertaken by the financial institution or their
		advisor. Based on the project review, the project is assigned a category.
2	Environmental	This requires that for Category A and B projects, an Environmental and Social Impact
	& Social	Assessment (ESIA) is done. The Principle provides guidance and an illustrative list of
	Assessment	issues the ESIA study should address. In addition, the Principle requires an
		assessment of potential adverse human rights impacts and climate change risks.
3	Applicable	The Equator Principle 3 requires that an assessment process comply with relevant
	Environmental	host country laws. In addition, for projects located in Non-Designated Countries
	and Social	(such as Azerbaijan), compliance with IFC Performance Standards on Environmental
	Standards	and Social Sustainability (Performance Standards) is required.
4	E&S	The financing institution will require the client to develop or maintain an
	Management	Environmental and Social Management System (ESMS) for all category A and B
	System and EP	projects. In addition, the Client must prepare an Environmental and Social
	Action Plan	Management Plan (ESMP).
7	Independent	An independent E&S review will be undertaken for Category A and B projects on the
	Review	EIA, ESMP, ESMS, SEP, and others as applicable, and an Equator Principle Action Plan
		(EPAP) will be prepared.
8	Covenants	The Principle requires that the Client covenant and comply with ESMP and EPAP
		requirements and provide periodic reports to document compliance with ESMP and
		EPAP and local E&S regulations.
9	Independent	After the financial close, for category A and B projects, the financing institution will
	Monitoring	require independent monitoring and reporting to assess project compliance with
	and Reporting	Equator Principles.
10	Reporting and	Identifies E&S reporting requirements for the client for category A and B projects.
	Transparency	

3.1.4 International Finance Corporation (IFC)

According to the IFC's Performance Standard 1, the client must "*establish and maintain a process for identifying the environmental and social risks and impacts of a project*." As part of this process, "*the risks and impacts identification process will consider the emissions of greenhouse gases (GHGs), the relevant risks associated with a changing climate and the adaptation opportunities, and potential transboundary effects, such as pollution of air, or use or pollution of international waterways*". For projects expected to generate more than 25,000 tonnes of CO2 equivalent (tCO2e) per year of GHG emissions, quantifying the direct and indirect emissions within the Project boundaries shall also be carried out in line with an internationally recognized methodology.

Applicable and considered IFC Performance Standard Requirements for the CCRA are listed in the table below:

Table 2 IFC Performance Standard Requirements



IFC PS	Key Points	(Direct/Indirect)
		related to CCRA
PS1:	PS1 underscores the importance of managing social and environmental	Directly related
Assessment	performance throughout the life of a project by using a dynamic social and	to CCRA
and	environmental management system. Specific objectives of this Performance	
Management	Standard are:	
Of Environmental	 To identify and assess social and environmental impacts, both adverse and heneficial in the preject's error of influence. 	
environmental	To avoid, or where avoidance is not nessible, minimize, mitigate, or	
Bicks and	- To avoid, of where avoidance is not possible, minimize, mitigate, of	
Imnacts	the environment:	
impuets	 To ensure that affected communities are appropriately engaged on 	
	issues that could potentially affect them; and	
	 To promote improved social and environmental performance of 	
	companies through the effective use of management systems.	
PS 3: Resource	This Performance Standard outlines a project approach to pollution	Directly related
Efficiency and	prevention and abatement in line with internationally available	to CCRA
Pollution	technologies and practices. It promotes the private sector's ability to	
Prevention	integrate such technologies and practices as far as their use is technically	
	and financially feasible and cost-effective in the context of a project that	
	relies on commercially available skills and resources. Specific objectives of	
	this Performance Standard are:	
	 To avoid or minimize adverse impacts on human health and the 	
	environment by preventing or minimizing pollution from project	
	activities and	
	Io promote the reduction of emissions that contribute to climate change	
ΡςΔ·	This PS recognizes that project activities equipment and infrastructure	Indirectly
Community	often benefit communities including employment services and	related to CCRA
Health, Safety	opportunities for economic development. However, projects can also	
and Security	increase risks arising from accidents, releases of hazardous materials,	
,	exposure to diseases, and the use of security personnel. While	
	acknowledging the public authorities' role in promoting the health, safety,	
	and security of the public, this PS addresses the project sponsor's	
	responsibility regarding community health, safety, and security.	
PS5: Land	Involuntary resettlement refers to physical and economic displacement due	Indirectly
Acquisition	to project-related land acquisition. Where involuntary resettlement is	related to CCRA
and	unavoidable, appropriate measures to mitigate adverse impacts on	
Involuntary	displaced persons and host communities should be carefully planned and	
Resettlement	implemented.	
PS6:	This Performance Standard reflects the Convention on Biological Diversity's	Indirectly
Biodiversity	objectives to conserve biological diversity and promote the use of	related to CCRA
conservation	renewable natural resources sustainably. This Performance Standard	
allu Sustainablo	audiesses now project sponsors can avoid or miligate threats to biodiversity arising from their operations and sustainably manage	
Management	renewable natural resources. Specific objectives of this Derformance	
of Living	Standard are:	
Natural	 To protect and conserve biodiversity and 	
Resources	 To promote the sustainable management and use of natural resources 	
	through the adoption of practices that integrate conservation needs and	
	development priorities.	



3.1.5 <u>European Bank for Reconstruction and Development (EBRD)</u>

The EBRD has established a thorough set of Performance Requirements (PRs) covering essential aspects of environmental and social sustainability, which projects must adhere to. Key to these requirements is the implementation of the mitigation hierarchy and adherence to international best practices⁴.

Applicable and considered EBRD Performance Requirements for the CCRA are listed in the table below:

Table 3	EBRD	Performance	Requirements
---------	------	-------------	--------------

EBRD PRs	Key Points
PR 1:	The objectives of this Performance Requirement are:
Assessment	
and	 "To identify and assess environmental and social impacts and issues, both adverse
Management	and beneficial, associated with the project."
of	• "To adopt measures to avoid, or where avoidance is not possible, minimize, mitigate,
Environmental	or offset/compensate for adverse impacts on workers, affected communities, and
and Social	the environment."
Risks and	 "To identify and, where feasible, adopt opportunities to improve environmental and
Impacts	social performance."
	 "To promote improved environmental and social performance through a dynamic
	process of performance monitoring and evaluation."5
PR 3:	The objectives of this Performance Requirement are:
Resource	
Efficiency and	 "To identify and assess environmental and social impacts and issues, both adverse
Pollution	and beneficial, associated with the project."
Prevention	• "To adopt measures to avoid, or where avoidance is not possible, minimize, mitigate,
and Control	or offset/compensate for adverse impacts on workers, affected communities, and
	the environment."
	"To identify and, where feasible, adopt opportunities to improve environmental and
	social performance."
	 "To promote improved environmental and social performance through a dynamic
	process of performance monitoring and evaluation."6

3.1.6 <u>ADB</u>

The Asian Development Bank (ADB) Safeguard Policy Statement⁷ adopted in 2009 is aligned and consistent with the IFC policies, integrating previous ADB policies and Safeguard Requirements on environment, involuntary resettlement and Indigenous Peoples under it. The objectives of the environmental safegaurds is to ensure the environmental soundness and sustainability of projects and to support the integration of environmental considerations into the project decision-making process. ADB requires comprehensive environmental assessments for its

5 ESP_PR01_Eng.pdf (ebrd.com)

⁴ Environmental and Social Policy. (2019). In European Bank for Reconstruction and Development (EBRD). Environmental and Social Policy (ebrd.com)

⁶ ESP_PR03_Eng.pdf (ebrd.com)

⁷ ADB Safeguard Policy Statement. (2009) https://www.adb.org/sites/default/files/institutional-document/32056/safeguard-policy-statement-june2009.pdf



projects to identify potential environmental impacts, including detailed analysis of climate change risks and vulnerabilities.

3.1.7 <u>AIIB</u>

The Asian Infrastructure Investment Bank (AIIB) has a comprehensive Environmental and Social Framework (ESF)₈ that integrates climate change considerations into its policies and operations. The ESF aims to ensure that the projects financed by AIIB are environmentally and socially sustainable, and it reflects the Bank's commitment to addressing climate change.

- The Environmental and Social Policy requires projects to undergo a climate risk and vulnerability assessment to identify potential climate-related risks and ensure resilience. This includes evaluating the impact of climate change on project performance and longevity. The policy requires the estimation and reporting of GHG emissions for relevant projects. It encourages the implementation of measures to reduce emissions and enhance carbon sequestration.
- The Environmental and Social Standards also requires the assessment of climate change risks and the integration of appropriate mitigation and adaptation measures into project design and implementation. In addition, it focuses on resource efficiency, including energy use, and the reduction of pollution, including GHG emissions. It promotes the use of clean and renewable energy sources.

4 Climate Change Risk Assessment

This section evaluates previous climatic events and trends through the analysis of historical data to understand the change of the climate conditions over time. Examining these historical patterns forms a basis for improving the understanding of future projections and predicting potential climate scenarios. Based on the available historical and projected data, the future climate risks are evaluated and strategies to mitigate and adapt to expected climatic changes are determined.

⁸ Environmental and Social Framework, Approved February 2016 (Amended February 2019, May 2021 and November 2022). https://www.aiib.org/en/policies-strategies/_download/environment-framework/AIIB-Environmental-and-Social-Framework_ESF-November-2022-final.pdf



4.1 Approach & Methodology

The figure below outlines the main steps to complete a qualitative assessment for physical risks aligned with the TCFD process for applying scenario analysis of climate related.



4.2 Baseline Climate Overview

Azerbaijan boasts a highly diverse climate, featuring nine of the eleven global climate zones. These range from semi-arid regions in the central and eastern parts, including Baku, to temperate zones in the north, continental climates in the west, and cold and tundra regions. Consequently, there's a wide range of annual temperatures and precipitation levels across the country. Generally, the mountainous regions experience more precipitation and cooler temperatures, while the central lowlands and Caspian Sea coast have a drier, hotter climate. Summers are particularly hot in the lowland areas, and winters are moderate (WBG & ADB, 2021)9.

In the hottest months of July and August, average temperatures in Baku and other eastern and southeastern regions typically reach around 27°C, while in the mountainous north and west, temperatures range between 15°C and 20°C during the same period. During winter (December to February), Baku experiences average temperatures of about 3°C to 4°C, whereas temperatures in the western and northern areas plummet to between -5°C and -10°C. Rainfall in Azerbaijan displays a bimodal distribution throughout the year, with average levels surpassing 40 millimetres (mm) per month from April to June and again in October. The peak precipitation occurs in May and June in the northern and western parts of Azerbaijan, where it can exceed 100 mm per month (CCKP, 2024).

⁹ WBG & ADB. (2021). Climate Risk Country Profile: Azerbaijan (2021): The World Bank Group and Asian Development Bank. https://www.adb.org/sites/default/files/publication/707466/climate-risk-country-profile-azerbaijan.pdf



The following figure presents the average monthly temperature and precipitation from 1991 till 2020 in the Project area. The highest average maximum temperature of 33°C and the lowest average minimum temperature of 0.84°C were recorded in July and January respectively. The annual mean temperature in the Project area was recorded at 15.39°C in 1991, increasing to 16.59°C in 2022. The highest precipitation levels of 51.75mm are recorded in October compared to the lowest levels of 17.43mm in July (CCKP, 2024).



Figure 3 Average Monthly Climate Conditions in the Project Area for 1991-2022 (CCKP, 2024)

Table 4 Average Monthly Mean Air Temperature and Precipitation in the Project Area (CCKP, 2024)

Parameter		Feb.	Mar.	Apr.	May.	Jun.	Jul.	Aug.	Sep.	Oct.	Nov.	Dec.
Temperature (°C)	4.6	5.4	8.8	14.5	19.4	24.8	27.3	26.9	22.8	16.9	10.8	5.6
Precipitation (mm)	25.2	36.3	36.6	35.6	40.2	28.9	17.4	18	25.6	51.6	40.1	25.8

4.3 Projected Climate Future and Physical Risks

The primary data source for the World Bank Group's Climate Change Knowledge Portal (CCKP), which has been used as the primary source for identifying projections in this section, is the Coupled Model Inter-comparison Project Phase 5 (CMIP5) models, which are utilized within the Fifth Assessment Report (AR5) of the Intergovernmental Panel on Climate Change (IPCC), providing estimates of future temperature and precipitation.



In that portal, the future climate projections have been developed the formulation of societal development narratives under the Shared Socioeconomic Pathways (SSPs). The SSPs consider societal factors such as demographics, human development, economic growth, inequality, governance, technological change and policy orientations. These variables were chosen based on their common use as inputs to emissions or impact models and their relationships to each other. Several SSP scenarios, SSP1-2.6, SSP2-4.5, SSP3-7.0, and SSP5-8.5 are presented on the portal.

The SSP2-4.5and SSP5-8.5will be used for this assessment to determine future trends and apply these to the Project:

- **SSP2-4.5** is approximately in line with the upper end of aggregate Nationally Determined Contribution emission levels by 2030. It represents assessed temperature projections for NDCs to be between 2.7 and 3.4°C by 2100, corresponding to the upper half of projected warming under SSP2-4.5. New or updated NDCs by the end of 2020 did not significantly change the emissions projections up to 2030, although more countries adopted 2050 net zero targets in line with SSP1-1.9 or SSP1-2.6. The SSP2-4.5 scenario deviates mildly from a 'no-additional- climate-policy' reference scenario, resulting in a best-estimate warming around 2.7°C by the end of the 21st century relative to 1850-1900.
- **SSP5-8.5** is a high reference scenario with no additional climate policy. Emission levels as high as SSP5-8.5 are not obtained by Integrated Assessment Models (IAMs) under any of the SSPs other than the fossil fueled SSP5 socioeconomic development pathway.

The Project commercial operation date (COD) is expected in January 2027, therefore, the potential climate change scenarios under the Coupled Model Inter-comparison Projects 6 (CMIP6) during the Project's lifetime till 2052 were obtained from CCKP. The applicable parameters are discussed in detail in the sections below.

4.3.1 <u>Temperature</u>

4.3.1.1 Future Scenarios

1- Mean temperature

<u>Under scenario SSP2-4.5, for the time period 2020-2039</u>, the average mean surface air temperature in the Project area is projected to be the highest in July where the 10-90th percentile range is 29.40°C to 30.90°C (median 30.13°C). The lowest temperature is expected in January where the 10-90th percentile range is expected at 4.31°C to 6.01°C (median 4.86°C). The 50th percentile for the projected annual average mean surface air temperature anomaly for 2020-2039 for the Project area (Ref. Period: 1995-2014), is highest in July at 1.47°C increase.



Scapilals

Figure 4 Projected Climatology (Left) and Anomaly (Right) of Average Mean Surface Air Temperature for 2020-2039 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5, Multi-Model Ensemble

<u>Under scenario SSP2-4.5, for the time period 2040-2059</u>, the average mean surface air temperature in the Project area is projected to be the highest in July where the 10-90th percentile ranges between 30.27°C to 31.82°C (median 31.13°C). The lowest temperature is expected in January where the 10-90th percentile range is 4.53°C to 6.44°C (median 5.49°C). The 50th percentile for the projected annual average mean surface air temperature anomaly for 2040-2059 for the Project area (Ref. Period: 1995-2014), is highest in July at 2.37°C.



Figure 5 Projected Climatology (Left) and Anomaly (Right) of Average Mean Surface Air Temperature for 2040-2059 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5, Multi-Model Ensemble

As presented in the following figure, under scenario SSP2-4.5, in 2027, the 10-90th percentile range of average mean surface air temperature in the Project area is expected to be 16.53°C to 18.47°C (median 17.13°C). By 2052, the 10-90th percentile range of average mean surface air temperature in the Project area is expected to reach 17.06°C to 19.17°C (median 17.96°C).





Figure 6 Projected Average Mean Surface Air Temperature for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5, Multi-Model Ensemble

<u>Under scenario SSP5-8.5, for the time period 2020-2039</u>, the average mean surface air temperature in the Project area is expected be highest in July where the 10-90th percentile range is 29.44°C to 31°C (median 30.36°C). The lowest temperature is expected in January where the 10-90th percentile range is 4.12°C to 6.24°C (median 5.06°C). The 50th percentile for the projected annual average mean surface air temperature anomaly for 2020-2039 for the Project area (Ref. Period: 1995-2014), is highest in August at 1.74°C.



Figure 7 Projected Climatology (Left) and Anomaly (Right) of Average Mean Surface Air Temperature for 2020-2039 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP5-8.5, Multi-Model Ensemble

<u>Under scenario SSP5-8.5, for the time period 2040-2059</u>, the average mean surface air temperature in the Project area is highest in July where the 10-90th percentile ranges between 30.32°C to 32.84°C (median 31.83°C). The lowest temperature is in January where the 10-90th



percentile range is expected at 5.09°C to 7.76°C (median 5.96°C). The 50th percentile for the projected annual average mean surface air temperature anomaly for 2040-2059 for the Project area (Ref. Period: 1995-2014), is highest in August at 3.21°C.



Figure 8 Projected Climatology (Left) and Anomaly (Right) of Average Mean Surface Air Temperature for 2040-2059 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP5-8.5, Multi-Model Ensemble

As presented in the following figure, under scenario SSP5-8.5, in 2027, the 10-90th percentile range of average mean surface air temperature in the Project area is expected to range between 16.36°C and 18.27°C (median 17.29°C). By 2052, the 10-90th percentile range of average mean surface air temperature in the Project area is expected to reach a range of 17.47°C to 20.12°C (median 18.54°C).



Model Ensemble

The table below presents the projected anomaly changes in temperature between the Projects COD compared to the end of operation. This encompasses the minimum, maximum and average daily temperature values, offering a comprehensive view of the expected temperature variation.



Scenario	Average Daily Maximum Temperature (Median & 10 th - 90 th percentile range)		Average Daily Temperature		Average Daily Minimum Temperature Scenario	
Years (Time Period)	2027	2052	2027	2052	2027	2052
RCP4.5	21.89°C	22.93°C	17.13°C	17.96°C	12.28°C	13.06°C
	(21.34°C -	(21.78°C -	(16.53°C -	(17.06°C -	(11.61°C -	(12.26°C -
	23.55°C)	24.00°C)	18.47°C)	19.17°C)	13.42°C)	14.31°C)
RCP8.5	22.19°C	23.56°C	17.29°C	18.54°C	12.43°C	13.57°C
	(21.16°C -	(22.32°C -	(16.36°C -	(17.47°C -	(11.49°C -	(12.53°C -
	23.21°C)	25.12°C)	18.27°C)	20.13°C)	13.33°C)	15.37°C)

Table 5 Projected Anomaly Changes in Temperature in the Project Region

2- Extreme Weather & Heatwaves

Primarily, increases in heatwave probability simply reflect the general increase in ambient temperatures, which constantly move away from the baseline Period 1995-2014 against which heat wave is measured. Another lens through which to view extreme heat is the annual frequency of days in which temperatures breach 35°C.

Summer temperatures peak with an average July maximum of 31°C in Azerbaijan, reaching maximum temperature of 33°C in the Project area (CCKP, 2024). The historic climatology showing the number of hot days with maximum temperature above 35°C in the Project area (Ref. Period: 1995-2014) is shown in the graph below. In 1950, the median number of hot days with maximum temperature above 35°C was approximately 25 days annually (10th % of 15.25 days and 90th % of 21.47 days). The median number of hot days with maximum temperature above 35°C has increased in 2014 to a 50th percentile average approximately 42 days per year (10th % of 30.12 days and 90th % of 55.28 days).





Figure 10 Historical Climatology of Number of Hot Days (Tmax > 35°C) per Year for 1950-2014 in the Project Area, Multi-Model Ensemble

<u>Under scenario SSP2-4.5</u>, the number of hot days with maximum temperature above 35°C in the Project area is highest in July with a median of 15.38 days for the period 1995-2014, projected to increase to 20.92 days for 2020-2039 and to further increase to 23.46 days for 2040-2059. In 2027, the COD of the Project, the projected number of hot days with maximum temperature above 35°C is 49.45 days (median), increasing throughout the Project lifetime to reach 62.41 days (median) in 2052.



Figure 11 Projected Number of Hot Days (Tmax > 35°C) for the Project Area (2020-2039), SSP2-4.5, 50th Percentile

5 capilals



Figure 12 Projected Number of Hot Days (Tmax > 35°C) for the Project Area (2040-2039), SSP2-4.5, 50th Percentile

<u>Under scenario SSP5-8.5</u>, the number of hot days with maximum temperature above 35°C in the Project area is highest in July with a median of 15.38 days for the period 1995-2014, projected to increase to 21.32 days for 2020-2039 reaching 25.4 days in the period of 2040-2059. In 2027, the COD of the Project, the projected number of hot days with maximum temperature above 35°C is 51.13 days (median), increasing throughout the Project lifetime to reach 69.54 days (median) in 2052.







Figure 14 Projected Number of Hot Days (Tmax > 35°C) for the Project Area (2040-2039), SSP5-8.5, 50th Percentile





Figure 15 Projected Climatology of Number of Hot Days (Tmax > 35°C) per Year for the Project Area (Ref. Period: 1995-2014), SSP2-4.5 and SSP5-8.5, Multi-Model Ensemble

3- Bushfire Weather

Studies suggest that climate change will have a significant impact on future fire. Suitable weather conditions (hot, dry and windy) must generally exist for fires to spread. Given the combination of factors required for increased bushfire conditions, the potential increase in the future will rely heavily on projected changes in the weather.

There is high confidence that climate change will result in harsher fire weather in the future. This is seen in the mean changes and when examining individual models and scenarios. However, there is low confidence in the magnitude of the change, as this is strongly dependent on the rainfall projection.

According to the ThinkHazard website, the projected climate changes suggest that Azerbaijan is likely to experience more frequent occurrences of fire weather, characterized by higher temperatures and greater variability in rainfall patterns. For regions already susceptible to wildfires, this could mean longer fire seasons with more days conducive to fire spread due to extended dry periods. Climate models also indicate a potential increase in fire severity. Even areas with historically low wildfire risk might see an increase in hazard levels as the wildfire-prone zone expands according to climate projections. In the Project area, the wildfire hazard is classified as high according to the information that is currently available to this tool, indicating more than 50% chance of encountering weather that could support a significant wildfire10.

¹⁰ ThinkHazard. Accessed June 2024. https://thinkhazard.org/en/report/19-azerbaijan/WF





Figure 16 Indication of Projected Wildfire (ThinkHazard, 2024)

In 2014, hot and dry weather conditions during the summer exacerbated drought conditions in Azerbaijan. Record-breaking temperatures were observed across various regions in August, leading to significant environmental impacts. The prolonged drought severely affected forested areas, causing damage to forest cover. As a consequence of these adverse conditions, twelve separate fire incidents were reported that year, resulting in the burning of approximately 58.8 hectares of forest land11.

The Project site and surrounding area is composed of various mixes of desert/grasslands and shrubs and therefore, bushfire weather may potentially impact the Project. The impacts of increased temperature that could lead to fires has been assessed in section 4.3.1.2 of this report.

4- Extreme Cold Weather

The historic climatology showing the number of ice days with maximum temperature below 0°C in the Project area (Ref. Period: 1995-2014) is shown in the graph below. In 1950, the median number of ice days with maximum temperature below 0°C was approximately 0.39 days annually (10^{th} % of 0.03 days and 90th % of 2.14 days). The median number of ice days with maximum temperature below 0°C has decreased in 2014 to a 50th percentile of 0.19 days per year (10^{th} % of 0.01 days and 90th % of 3.43 days).

¹¹ Ministry of Ecology and Natural Resources Republic of Azerbaijan. (2015). Third National Communication to the United Nations Framework Convention on Climate Change Republic of Azerbaijan. https://unfccc.int/resource/docs/natc/azenc3.pdf





Figure 17 Historical Climatology of Number of Ice Days (Tmax < 0°C) in the Project Area for 1950-2014

<u>Under scenario SSP2-4.5</u>, the number of ice days with maximum temperature below 0°C in the Project area is highest in January with a median of 0.68 days for the period 1995-2014, projected to decrease to 0.26 days for 2020-2039 and increase to 0.29 days for 2040-2059. In 2027, the COD of the Project, the projected number of ice days with maximum temperature below 0°C is 0.09 days (median), slightly fluctuating throughout the Project lifetime, yet remaining below 0.2 days to reach 0.03 days (median) in 2052.

<u>Under scenario SSP5-8.5</u>, the number of ice days with maximum temperature below 0°C in the Project area is highest in January with a median of 0.68 days for the period 1995-2014, projected to decrease to 0.35 days for 2020-2039 reaching 0.15 days for 2040-2059. In 2027, the COD of the Project, the projected number of ice days with maximum temperature below 0°C is 0.07 days (median), slightly fluctuating throughout the Project lifetime, yet remaining below 0.3 days to reach 0.04 days (median) in 2052.

4.3.1.2 Risk Assessment and Mitigation

As per the CCKP, the average daily maximum temperature in 2027 is 22.19°C compared to 23.56°C in 2052. However, during the summer months of July and August over the project's lifetime, the Project area may witness extreme temperatures projected to exceed 35°C, with more than 3°C increase from current temperatures. Hence, if the project components are not chosen and designed to withstand these high temperatures, the anticipated temperature rise could potentially impact the power generation of the PV system, accelerate the aging of its components, and elevate the risk of fire.



As per the CCKP, projected extreme cold temperatures of 0°C are expected for very few days annually during the Project lifetime. Cold weather can have both positive and negative impacts on solar PV Projects. Solar PV panels operate more efficiently at cooler temperatures which can improve overall efficiency especially when cold weather is accompanied with clear, sunny skies or in the presence of snow which can temporarily reflect sunlight onto the panels once it melts or is cleared away. This can enhance energy production during the winter months. However, heavy snow accumulation or ice formation on solar panels could potentially reduce or completely block sunlight from reaching them.

To ensure the efficiency and reliability of the Project components, the Solar panels have been selected with operating temperatures of 45°C. To further mitigate extreme heat events and increased temperature, the detailed design and procurement shall ensure that all equipment and machines allow continuous operation at rated power (or rated current), in the full range of site conditions, without exceeding applicable temperature and temperature rise limits (35°C) or failing upon exceptional electric and electromechanical stresses.

To mitigate fire risks, the Project shall be equipped with a fire protection system that features comprehensive fire detection and response facilities. The Project design shall consider fire-resistant materials for mounting structures, cabling, and other components. Installing advanced monitoring systems to detect issues early, such as reduced output due to smoke or potential damage from heat, allowing for timely interventions may be considered.

To mitigate extreme cold conditions, the Solar PV systems should be designed with features such as tilt angles optimized for snow shedding, or if possible, heating elements to prevent snow buildup on panels. Regular maintenance is crucial in cold climates to ensure panels remain clear of snow and ice and that any system components affected by cold temperatures are properly maintained.

Acute physical climate risks relevant to the Project include health and safety incidents amongst operational plant workers during periods of extreme heat. The incidence of substantially high temperatures could potentially impact on the wellbeing of workers, particularly those who will not operate within units with controlled temperatures. Workers stationed in the Plant's exterior, for instance, will be prone to health effects such as dehydration, and heat stress, heat stroke, heat exhaustion, heat cramps, heat rashes and burns from contact with overheated surfaces. To ensure the safety of the workers, the following measures are proposed:

- Induction and refresher health and safety (H&S) trainings will include trainings on prevention of and first response to extreme heat/cold exposure. The trainings will cover risk factors, mitigating Personal Protective Equipment (PPE), first aid measures and nearest health centre for treatment of hyperthermia or hypothermia.
- Ensure all workers receive worker induction and regular ongoing training (e.g., toolbox talks, work briefings) on the health and safety risks of extreme weather conditions.



- Ensure the availability of medical facilities and nurses as well as first aid and transport for medical emergencies.
- Workers assigned to operations in the exterior of the Plant's buildings and shaded areas will be provided with appropriate PPE (e.g., sun hats and cooling vests).
- Shaded resting areas and adequate access to sufficient potable water will be provided for workers and maintenance staff stationed outside of the Plant's buildings.
- Work locations (and duration, to the extent possible) will be restricted during periods of extreme heat or cold to lessen the risk of heat/cold-related health effects. Maintenance work within high/cold-temperature units will be avoided during days with inordinately high/low temperatures.
- Staff rooms on the plant's premises will be equipped with air conditions/fans/heaters to enable operations at workstations during periods of extreme heat/cold.
- Monitor weather forecast and halt outdoor maintenance work in any expected events of extreme weather conditions (rainstorm, extreme cold, extreme heat waves, high wind etc.).
- All workers will be entitled to health insurance and sick leaves in accordance with national Labour Law.
- Further information and management plans to address workers welfare will be included in the Project H&S Plan.

4.3.2 <u>Precipitation</u>

4.3.2.1 Future Scenarios

<u>Under scenario SSP2-4.5, for the time period 2020-2039</u>, the average precipitation in the Project area is projected to be the highest in April where the 10-90th percentile range is 43.98mm to 55.49mm (median 50.24mm). The lowest precipitation is expected in July where the 10-90th percentile range is expected at 10.22mm to 17.93mm (median 13.49mm). The 50th percentile for the projected annual precipitation anomaly for 2020-2039 for the Project area (Ref. Period: 1995-2014), is highest in March with 3.49mm increase (10-90th percentile range of -2.39mm to 9.42mm).



Figure 18 Projected Precipitation Climatology (Left) and Anomaly (Right) for 2020-2039 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5, Multi-Model Ensemble



<u>Under scenario SSP2-4.5, for the time period 2040-2059</u>, the average precipitation in the Project area is projected to be the highest in March where the 10-90th percentile range is 41.61mm to 55.5mm (median 49.62mm). The lowest precipitation is expected in August where the 10-90th percentile range is expected at 7.99mm to 17.70mm (median 13.35mm). The 50th percentile for the projected annual precipitation anomaly for 2020-2039 for the Project area (Ref. Period: 1995-2014), is highest in November with 4.77mm increase (10-90th percentile range of -3.38mm to 13.73mm).



Figure 19 Projected Precipitation Climatology (Left) and Anomaly (Right) for 2040-2059 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5, Multi-Model Ensemble

As presented in the following figure, under scenario SSP2-4.5, in 2027, the 10-90th percentile range of precipitation in the Project area is expected to be 323.04mm to 502.07mm (median 426.49mm). By 2052, the 10-90th percentile precipitation in the Project area is expected to reach a range of 346.73mm to 508.75mm (median 405.40mm).



Figure 20 Projected Precipitation for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5, Multi-Model Ensemble

<u>Under scenario SSP5-8.5, for the time period 2020-2039</u>, the average precipitation in the Project area is projected to be the highest in April where the 10-90th percentile range is



43.14mm to 57.78mm (median 48.72mm). The lowest precipitation is expected in July where the 10-90th percentile range is expected at 10.31mm to 18.04mm (median 16.2mm). The 50th percentile for the projected annual precipitation anomaly for 2020-2039 for the Project area (Ref. Period: 1995-2014), is highest in November with 2.74mm increase (10-90th percentile range of -6.10mm to 10.12mm).



Figure 21 Projected Precipitation Climatology (Left) and Anomaly (Right) for 2020-2039 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP5-8.5, Multi-Model Ensemble

<u>Under scenario SSP5-8.5, for the time period 2040-2059</u>, the average precipitation in the Project area is projected to be the highest in April where the 10-90th percentile range is 43.14mm to 57.78mm (median 48.72mm). The lowest precipitation is expected in July where the 10-90th percentile range is expected at 10.31mm to 18.04mm (median 16.2mm). The 50th percentile for the projected annual precipitation anomaly for 2020-2039 for the Project area (Ref. Period: 1995-2014), is highest in November with 6.13mm increase (10-90th percentile range of -4.61mm to 12.81mm).



Figure 22 Projected Precipitation Climatology (Left) and Anomaly (Right) for 2040-2059 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP5-8.5, Multi-Model Ensemble

As presented in the following figure, under scenario SSP5-8.5, in 2027, the 10-90th percentile range of precipitation in the Project area is expected to be 340.17mm to 492.55mm (median 423.89mm). By 2052, the 10-90th percentile precipitation in the Project area is expected to reach a range of 308.05mm to 518.96mm (median 421.96mm).
5 capilals



Figure 23 Projected Precipitation in the Project Region; (Ref. Period: 1995-2014), SSP5-8..5, Multi-Model Ensemble

For the Project operational period, across all scenarios, the anticipated median (50th percentile) precipitation is expected to remain comparable to historical patterns, showing fluctuations without significant projected increases in the future. Considering the rainfall projections, significant impacts due to increased precipitation is not expected.

1- Floods

According to the Climate Country Profile Report of WBG & ADB in 2021₁₂, Azerbaijan experiences frequent flooding which typically occurs in late spring and early summer in higher altitude areas of the country (above 1,500 m in altitude), whereas in lower areas, flooding may occur in spring or autumn. The parts of the country at greatest risk of floods are in the central and south-eastern regions, while some parts of the country, such as the south slope of the Greater Caucasus, experience mudflows caused by flooding.

Severe flooding occurred in Azerbaijan in 1995, affecting 1.5 million people and resulting in approximately \$30 million losses. In 2003, severe floods impacted 30,000 people, resulting in over \$70 million in damage. Azerbaijan's water resources depend primarily on two key river basins, that of the Kur and Aras rivers. The future hydrology of their basins, including the greater and lesser Caucasus mountain ranges, will likely determine fluvial flooding trends.

To determine the flood risks at the Project site, a Hydrometeorological Study was prepared by JURU in 2024. For flood risk the direct rainfall method (DRM) is employed. DRM involves directly

¹² WBG & ADB. (2021). Climate Risk Country Profile: Azerbaijan (2021): The World Bank Group and Asian Development Bank. https://www.adb.org/sites/default/files/publication/707466/climate-risk-country-profile-azerbaijan.pdf



applying rainfall to the hydrodynamic surface-flow model. For soil data, the Global Hydrological Soil Groups (HYSOGs250m) were used. This allows to create an infiltration layer with the Deficit Constant, Soil Conversation Service (SCS) Curve Number, and Green and Broad methods. Historical 3 hours, 12 hours and 24 hours rainfall data from the Bilasuvar meteorological station for the past 20-30 years was used for the model. Due to the unavailability of observed rainfall data for time intervals smaller than 3 hours, an extrapolation adjustment was made. As a result of this extrapolation adjustment, it was possible to determine the values of precipitation amount up to the amount that can fall in an interval of up to 30 minutes.

The following maps present the four different scenarios of annual exceedance probability (AEP) flood depth and flood flow velocity. The 10% AEP flood depth (10 years return period), indicates that the majority of the Project area will be subject to 0.1m and 1m with limited areas of 1m to 2m flood depth. These areas expand in the remaining three scenarios, 5% (20 years return period), 2% (50 years return period) and 1% (100 years return period) with the majority of the site experiencing flood levels 0.7m to 1m flood depth and larger areas experiencing flood depth reaching 2m flood depth. Similarly, the flood velocity under the 10% AEP flood flow velocity (10 years return period), ranges between 0.4m/s and 1.2m/s in the flooded areas with certain places reaching flow velocity of 2m/s. The flood flow velocity increases under the remaining three scenarios where larger areas of the site may experience flood flow velocity of 1.6m/s to 2m/s.



Figure 24 Map Showing the Modelling results 10% AEP Flood Depth (Left) Flood Velocity (Right) (Return period for 10 years)



Figure 25 Map Showing the Modelling results 5% AEP Flood Depth (Left) Flood Velocity (Right) (Return period for 20 years)

5 capilals



Figure 26 Map Showing the Modelling results 2% AEP Flood Depth (Left) Flood Velocity (Right) (Return period for 50 years)



Figure 27 Map Showing the Modelling results 1% AEP Flood Depth (Left) Flood Velocity (Right) (Return period for 100 years)

2- Drought

According to the Climate Country Profile Report of WBG & ADB in 2021₁₃, Azerbaijan may experience two primary types of drought, meteorological due to the lack of precipitation and hydrological, usually due to a deficit in surface and subsurface water flow, potentially from the region's larger river basins. Currently, Azerbaijan faces an annual median probability of severe meteorological drought of about 2%, defined by a standardized precipitation evaporation index (SPEI) of less than -2.26.

Naumann et al. (2018) referenced in the Climate Country Profile report provides a perspective on changes in drought conditions under different warming scenarios. They predict significant increases in the duration and magnitude of meteorological droughts in West Asia by the end of the 21st century under global warming levels of 1.5°C, 2.0°C, and 3.0°C. Droughts that are currently extremely rare in West Asia (100-year droughts) are projected to become 5 to 10 times more common under these warming scenarios. Similarly, model ensembles forecast a significant rise in the annual probability of severe drought by the 2090s. This rise is particularly notable in higher emissions pathways, with a projected increase in the median probability of severe drought from an observed 2% per year from 1986–2005 to a forecasted 73% or 85% by

¹³ WBG & ADB. (2021). Climate Risk Country Profile: Azerbaijan (2021): The World Bank Group and Asian Development Bank. https://www.adb.org/sites/default/files/publication/707466/climate-risk-country-profile-azerbaijan.pdf



the end of the century. These projections indicate a shift towards a chronically drought-affected environment in many parts of Azerbaijan, likely contributing to the expansion of arid ecosystems and desertification.

According to the ThinkHazard Platform, in the Project area (Shirvan-Salyan District) water scarcity is classified as **low** according to the information that is currently available to this tool. This means that there is a 1% chance drought will occur in the coming 10 years₁₄.

<u>Under scenario SSP2-4.5, for the time period 2020-2039</u>: As shown in the graphs below, the mean (50th percentile) SPEI in the Project region, is relatively similar to the historical trend with SPEI projected range of -0.02 to -0.03 compared to -0.02 to -0.06 in 1995-2014. The 10th percentile however shows a potential increase in drought events with SPEI reaching -0.34 in May. The 90th percentile shows a positive trend with the SPEI reaching 0.2 in May.

<u>Under scenario SSP5-8.5, for the time period 2020-2039</u>: As shown in the graphs below, the mean (50th percentile) SPEI in the Project region, shows a decrease in the drought index with projected climatology SPEI index reaching 0.05 index compared to -0.02 to -0.06 in 1995-2014. The 10th percentile however shows a potential increase in drought events with SPEI reaching - 0.3 in April. The 90th percentile shows a positive trend with the SPEI reaching 0.3 in March and December.



Figure 28 Projected Climatology of Annual SPEI Drought Index for 2020-2039 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5 (Left) SSP5-8.5 (Right), Multi-Model Ensemble

<u>Under scenario SSP2-4.5, for the time period 2040-2059</u>: As shown in the graphs below, the mean (50th percentile) SPEI in the Project region, shows a decrease in the drought index with projected climatology SPEI index reaching 0.04 index compared to -0.02 to -0.06 in 1995-2014. The 10th percentile however shows a potential increase in drought events with SPEI reaching - 0.31 in March. The 90th percentile shows a positive trend with the SPEI reaching 0.21 in March.

<u>Under scenario SSP5-8.5, for the time period 2040-2059</u>: As shown in the graphs below, the mean (50th percentile) SPEI in the Project region, shows a decrease in the drought index with projected climatology SPEI index reaching 0.07 index compared to -0.02 to -0.06 in 1995-2014.

¹⁴ ThinkHazard. Accessed June 2024. https://thinkhazard.org/en/report/548-azerbaijan-aran-salyan/DG



The 10th percentile however shows a potential increase in drought events with SPEI reaching - 0.21 in September. The 90th percentile shows a positive trend with the SPEI reaching 0.36 in January.



Figure 29 Projected Climatology of Annual SPEI Drought Index for 2040-2059 (Annual) for the Project Region; (Ref. Period: 1995-2014), SSP2-4.5 (Left) SSP5-8.5 (Right), Multi-Model Ensemble

Based on the data presented above, the Project region is at low risk of drought during the operational period where the 50th-90th percentile future trends predict more wet conditions and therefore lower drought risk.

4.3.2.2 Risk Assessment and Mitigation

Climate-induced natural disasters, such as floods, droughts, high-intensity rainfall events may interrupt the PV plant operations through severe damage to the panels, buildings, equipment and materials. Forced power outages resulting from natural hazards can therefore compound the risk of economic losses and stress to communities reliant on the power grid. This can also risk the safety of the Project workforce. Based on the projected rainfall data and flood risk modelling carried out by JURU, the site is at risk of floods and therefore, design mitigation will be required to ensure the safety of the Project, the workers and the surrounding sites. The following mitigation measures are proposed:

- Stormwater drainage systems shall be designed to withstand the maximum discharge in the most extreme foreseeable precipitation events to ensure no loss of operation for a flooding level with a return period of 1 in 100 years.
- Implement the mitigation measures presented in the Hydrometeorological Study prepared by JURU in 2024. These have not been included here to avoid repetition, the measures are presented in Chapter 5, 6 and 7 of Appendix A.
- Implement the mitigation measures discussed under section 4.3.1.2 of this report.

Water consumption during operation is expected to be minimal. Even though the drought index did not indicate a high risk of drought events in the Project area, a water management plan should be implemented to reduce the impacts on water resources. The plan should include the following:



- Installing smart water management systems (faucets with sensors, water meters, leakage detection systems etc.).
- Monitoring water consumption.
- Conducting regular maintenance of faucets, plumbing, water tanks etc.
- Raising awareness on water conservation among workers.

4.4 Transition Risks

Climate transition risks refer to those which may arise from the plans or processes that may be put in place to adjust to a lower-carbon, climate-resilient economy. These can include changes or updates to policy or legislation (e.g. introduction of emission limits), imposition of carbon tax, shifts in demand and supply due to technology and market changes and reputation risks reflecting changing customer or community perceptions (Equator Principles, 2020).

Given the Project is a Solar PV plant that aligns with transition to lower carbon economies, there are not expected to be specific risks related to future low carbon economies (policy, regulations etc.) or future public perceptions of the Project that are considered to be risks at this stage.



5 Appendix A - Hydrometeorological Study Prepared by JURU, 2024





PROJECT:	COMBINED CAPACITY OF 835MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-CONSTRUCTION BILASUVAR SOLAR PV
LOCATION:	BILASUVAR REGION, AZERBAIJAN
CLIENT:	ABU DHABI FUTURE ENERGY COMPANY PJSC - MASDAR
JURU REFERENCE:	
REVISION:	C
JURU ISSUE:	HYDROMETEOROLOGICAL STUDY REPORT
ISSUE DATE:	May 30, 2024

Juru Ltd. 71-75 Shelton Street Covent Garden London, United Kingdom, WC2H 9JQ T: +44 207 859 4028, F: +44 207 691 9406 E: info@juru.org





Revision History

Rev.	Date	Status	Originated	Checked	Approved
А	4.03.2024	Preliminary Hydrometeorological Report Issued for Client / Comment.	SHY	TD	
В	15.03.2024	Report updated in accordance Comments	SHY	TD	
С	30.05.2024	Report updated in accordance Comments (Page 53-54)	SHY	TD	

HOLD Record

Hold Ref.	Description / Reason for HOLD	Ref. Section







CONTENTS

ABBR	EVIATIONS	4
UNITS	5	4
1.	INTRODUCTION	5
1.1.	EXECUTIVE SUMMARY	5
1.2.	BACKGROUND	5
1.3.	PURPOSE AND OBJECTIVES OF RESEARCH	6
1.4.	SITE DESCRIPTION OF THE PROJECT	6
1.5.	CODES AND STANDARDS	7
2.	CLIMATIC CHARACTERISTICS OF THE TERRITORY	8
2.1.	FEATURES OF ATMOSPHERIC CIRCULATION IN THE REGION	10
2.2.	SOLAR RADIATION	12
2.3.	AIR TEMPERATURE REGIME	14
2.4.	REGIME OF RELATIVE HUMIDITY	17
2.5.	PRECIPITATION	19
2.6.	ATMOSPHERE PRESSURE	20
3.	HYDROLOGIC AND HYDRAULIC STUDIES	21
3.1.	OBJECTIVES AND WORK FLOW	21
3.2.	SCOPE OF WORKS	22
3.3.	DESIGN PRINCIPLES AND STANDARDS	23
3.4.	MAXIMUM RAINFALL INTENSITY AND DURATION WITH RETURN PERIODS	24
3.5.	DATA COLLECTION	26
3.5.1.	DIGITAL TERRAIN MODEL AND WATERSHED DEFINITIONS	26
3.5.2.	GEOLOGICAL STRUCTURES	32
3.5.3.	LAND USE LAND COVER DATA	33
3.5.4.	FLOOD HYDROGRAPH DETERMINATION WITH INFILTRATION	35
3.5.5.	RAINFALL INTENSITY-DURATION-FREQUENCY DEFINITION	37
4.	FLOOD HYDRAULIC MODEL RESULTS	43
5.	FLOOD MITIGATION	52
6.	RECOMMENDATIONS FOR CONSTRUCTION STRUCTURE	54
7.	CONCLUSION	56





ABBREVIATIONS

ASCE(Eng)	American Society of Civil Engineers
ASHRAE(Eng)	American Society of Heating, Refrigerating and Ambient- Conditioning Engineers
AP	Atmosphere pressure
GEV	Generalized Extreme Value
IDF (Eng)	Intensity duration frequency
MCDB (Eng)	Mean Coincident Dry Bulb Temperatures
MCWB (Eng)	Mean Coincident Wet Bulb Temperatures
DEM	Digital Elevation Model
SP (Russ)	Construction norm
WMO (Eng)	World Meteorological Organization
HEC-RAS	Hydrological Engineering Center's River Analysis System

UNITS

Length	km (m)
Area	km² (m²)
Volume	m ³
Velocity	m/s
Concentration	vol.%, wt.%, ppm (V), ppm
Time	hr, s
Frequency	Hz, %
Mass	kg, ton (t)
Density	kg/m³, mg/l
Mass flow rate (liquid and gas)	kg/hr
Mass flow rate (steam)	t/hr
Pressure	Pa, kPa, MPa, kg/cm ² , Bar
Energy	kcal, cal, J, kJ
Voltage	V, kV
Temperature	°C



A71-75 Shelton Street Covent Garden London, United Kingdom, WC2H 9JQ +44 207 859 4028, +44 207 691 9406 www.www.juru.org nfo@juru.org

Sheet 4



1. INTRODUCTION

Juru

1.1. EXECUTIVE SUMMARY

In 2020 Azerbaijan set a target of increasing the share of renewables in its electricity mix to 30% by 2030. As Azerbaijan is relatively sunny, it has excellent solar power potential. According to the Ministry of Energy, technical potential is around 23000 MW. The country's 2400 to 3200 sunshine hours annually compare well internationally, as does its solar intensity, estimated at 1500 to2 000 kWh/m². The best resources are in the central river valleys and the north and northwest.

On 4 Jun'22, the Ministry of Energy of the Republic of Azerbaijan and Masdar signed an Implementation agreement relating to the assessment, development and implementation of a 4 GWac pipeline of solar PV and onshore wind projects in the Republic of Azerbaijan starting with 2GWac as the first phase. The Implementation Agreement granted Masdar exclusive rights to develop Phase 1.

The Projects are being developed as a bilateral agreement between the Abu Dhabi Future Energy Company - Masdar and the Government of Azerbaijan. Masdar (hereinafter referred to "Company") will be responsible to build, own and operate the solar PV plants on Build, Operate & Own (BOO) basis.

The planned object is located in an open area 16 km to the northeast of Bilasuvar city. The total capacity of Bilasuvar solar power station is 445 MWac. The total area allocated for the project is 1420 hectares.

1.2. BACKGROUND

Engineering hydrometeorological studying on the object **COMBINED CAPACITY OF 445 MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-CONSTRUCTION BILASUVAR SOLAR PV PROJECT IN THE REPUBLIC OF AZERBAIJAN** were carried out by the specialists of **JURU Limited** on the basis of contract from ...2024.

For the implementation of engineering surveys for construction, **JURU Limited** has a Certificate of admission to work on the implementation of engineering surveys.

Carl Inc.	71-75 Shelton Street Covent Garden London, United Kingdom, WC2H 910	Sheet 5
Juru	€ info@juru.org	All sheets 57



Engineering and hydrometeorological surveys are carried out to study the meteorological conditions of the site where the project is being designed. As a result of the preparatory work, initial data on the hydrological regime of the climatic conditions of the region will be obtained. As a result of the survey, data on climatology necessary for the design of the facility will be obtained.

1.3. PURPOSE AND OBJECTIVES OF RESEARCH

The purpose of engineering and hydrometeorological surveys is a comprehensive study of the hydrometeorological conditions of the territory on which construction sites are located and the forecast of possible changes in these conditions as a result of interaction with the designed objects in order to obtain the necessary and sufficient materials for making informed design decisions.

The objective of this hydrological study is to develop and evaluate the existing drainage patterns and flow rates for the runoff tributary to the Project. The hydrology will be the base used to determine the location of the natural watercourses upstream and within the project area and the amount of runoff that flows in the existing watercourses.

1.4. SITE DESCRIPTION OF THE PROJECT

The Bilasuvar solar power plant project area is located in the northeast part of the city of Bilasuvar, Bilasuvar district of the Republic of Azerbaijan.

Bilasuvar is a city and the administrative center of the Bilasuvar region of Azerbaijan. It is located on the Mugan Plain, 44 km southwest of the Salyan railway station and 182 km from Baku.

The region borders in the north with Imishli, Saatli and Sabirabad, in the east with Salyan, in the southeast with Neftechala, in the south with Jalilabad districts, and in the west with the Islamic Republic of Iran.

The territory is located in the Absheron Peninsula on the Caspian Sea. The geological conditions of this region are associated with its location on the platform part of Transcaucasia. The area is dominated by Cretaceous and Paleogene sediments. The relief of the area is low, sloping towards the east. Most of the territory is located below sea level. The lowland consists of anthropogenic sediments. Chestnut, light chestnut, sierozem-meadow, alluvial-meadow and saline soils are common in the Bilasuvar region. Plants are predominantly desert and semi-desert types.

	2 71 75 Shalton Streat Covent Cardon London United Kingdom WC2H 010	Sheet 6
Juru	€ info@juru.org	All sheets 57



The climate in this area is continental, with hot summers and relatively mild winters. Mahmudchala swamps lake system is located in the western part of the planned Kuyosh power station.

The lake in its modern form was formed in 1896 as a result of a gigantic flood of the Araz River. After regulating the flow of the Araz River, the lake is fed by water from the Bolgarchay River and irrigation canals. After the creation of a reservoir on the Bolgarchay River in 1965, the area of the lake decreased significantly.

The lake's soil is mostly silty, in some places remains of aquatic plants predominate. The surrounding soils are of the carbonate alluvial-meadow type. Groundwater in the area is close to the surface and relatively saline.

In areas close to the surface (1.5-2.5 m) of the groundwater level, the salinity and saline content of the water are several times higher.

1.5. CODES AND STANDARDS

General technical requirements for performing engineering surveys, their composition and types are regulated by the following fundamental documents:

- ✓ ASCE/SEI 24-14. Flood Resistant Design and Construction
- ✓ ASCE 7. Minimum Design Loads for Buildings and Other Structures.
- ✓ AzDTN 2.1-1 "Load and impact"
- ✓ BS 85500:2015 Flood Resilient Construction
- ✓ BS 8533:2015 Assessing and managing flood risk in development.
- ✓ MSN 2.04-01-98 Construction climatology
- ✓ TR-55 Urban hydrology for small watersheds, United States Department of Agriculture USDA.
- ✓ EN1991-1-4: General actions Wind actions
- ✓ SN 63-76 Guidelines for the Analysis of Storm Water Runoff from Small Reservoirs
- ✓ FP 204-078-1. This policy updates and supersedes the Standards for Flood Risk Analysis and Mapping
- ✓ C□ 482.1325800.2020 "Engineering and hydrometeorological surveys for construction. Set of rules"

A	71-75 Shelton Street Covent Garden London, United Kingdom, WC2H 910	Sheet 7
Juru	€ info@juru.org	All sheets 57



2. CLIMATIC CHARACTERISTICS OF THE TERRITORY

Juru

The purpose of hydrometeorological surveys is to obtain the necessary data to assess the climatic conditions of the construction area and identify dangerous hydrometeorological phenomena. Based on climatic conditions, equipment is selected, technological parameters are calculated, loads on building structures are determined, the period of operation of facilities is determined, and the impact of structures on the environment is assessed.

To assess the climatic conditions of the survey area, a network of representative stations was selected, and materials from long-term observations were analyzed. Based on the results of meteorological surveys, a climate profile was compiled.

Climatic parameters include the temperature of the outside air, the speed of its movement, pressure, characteristics of changes in water vapor, the amount of precipitation, solar radiation.

Climatic characteristics for the survey area are given based on the nearest weather station.

The selection of a meteorological station to characterize the climatic conditions of the survey site was carried out in according to WMO No. 100 Guide to Climatological Practices, when data are available, it is recommended to use data from a weather station located at a distance of \leq 100 km. For construction located in mountainous areas, the selection of representative meteorological stations should be made taking into account the altitude above sea level, the exposure of mountain slopes, and the position relative to the valley bottom.

The study area has not been sufficiently studied meteorologically. The closest representative meteorological station to the survey site is the BILASUVAR meteorological station (AJ000037972).

Observation of meteorological elements consists of measurements at one-minute intervals. However, according to the requirements of WMO-No. 8 normative document of WMO, data recording is recorded in average amounts for the intervals of 03, 06, 09, 12, 15, 18, 21, 24 hours of Greenwich time.

During the survey, preliminary and field deciphering of available satellite images and cartographic materials was carried out, and data was collected to study the natural conditions of the study area.

1. A.	2 71 75 Shalton Street Covent Carden London United Vingdom WC2H 010	Sheet 8
Juru	₩www.www.juru.org 🖄 info@juru.org	All sheets 57

JUru Hydre





Figure 1.1: Study area Bilasuvar solar power station



2.1. FEATURES OF ATMOSPHERIC CIRCULATION IN THE REGION

Atmospheric circulation is one of the main climate-forming factors. Synoptic processes developing over the territory of Azerbaijan (over objects) are currently divided into 8 types.

The zonal transfer of air masses that dominates the territory of Transcaucasia is in some cases disrupted under the influence of interlatitudinal exchange, which causes intense invasions of cold air masses from the north and the removal of warm masses from the south. The Main Caucasus Ridge plays a large role in shaping the characteristics of circulation processes over the territory of Transcaucasia. The mountain ranges of the Caucasus are a natural

hindering the free spread of northern cold air masses. However, under certain conditions, cold air masses begin to flow around the ridge from the Caspian Sea and penetrate into the territory of Absheron, and therefore into Baku.

The Lesser Caucasus Mountain system also plays a significant role in the development of atmospheric processes in the city, due to which the moisture content and speed of warm air masses moving from the south mainly decrease. Frontal processes also have a certain influence on the climate of this region. Air masses formed on the polar and even Arctic fronts penetrate here.

Uneven heating of land and sea, as well as the presence of a weakly gradient pressure field in the coastal strip and some distance inland, contribute to the emergence of breezes. The unique physical and geographical position of the Territory, the proximity of the Caspian Sea and the complexity of the orographic conditions of the area create a wide variety of forms of local circulation. The synoptic processes developing over Transcaucasia, in particular over Absheron, which determine the climate of Baku, are divided into eight main types, depending on the main routes of penetration of air masses and their transformation.

In the cold half of the year, a characteristic feature of the development of atmospheric processes is the high frequency of meridional movements of cold masses of Arctic air in the rear part of the trough of northern cyclones, oriented through Central Europe to the Balkans, the Black Sea and the Caucasus. This situation contributes to the accumulation of cold air over the European part of the USSR and its breakthrough in a southern direction.



In winter, in most cases (about 20%), the weather is determined by local atmospheric circulation processes. In the presence of an area of high pressure or a blurred pressure field over the Caucasus, a transformation of the arriving air masses of temperate latitudes occurs.

Quite often, such processes lead to the formation of hair dryers, causing warm and dry weather. In 15% of cases, the weather in this area is influenced by an anticyclone located over the south and southeast of the European Union. When the continental anticyclone intensifies and there is an area of low pressure over the Caucasus, continental air from temperate latitudes invades. Sharp weather changes in winter are associated with the invasion of arctic air (about 10%) from Northwestern Siberia, from the Kara, Barents or Norwegian seas. Continental Arctic air in areas of high pressure moves south. At the same time, in the southern regions there is a revival of cyclonic activity and the entry of southern cyclones through Transcaucasia into the Southern Caspian Sea. Such a situation contributes to the intense invasion of Arctic air in the rear of southern cyclones, with a sharp drop in air temperature, increased cloudiness, and precipitation.

In the warm half of the year, the development of atmospheric processes is determined mainly by changes in the intensity of solar radiation. There is a weakening of the meridional circulation, which contributes to an increase in westerly transport. The restructuring of pressure systems in spring leads to the development of the Azores maximum and the weakening of the spur of the Siberian maximum. Intrusions of continental Arctic air almost completely stop.

Air masses moving from the north arrive in the Baku region greatly transformed. The increase in the frequency of local circulation processes (25%) is associated with the development of low-gradient high-pressure areas. There are processes leading to the removal of tropical air (21%), which causes a sharp increase in air temperature.

Features of the summer circulation are manifested in the weakening of advection and the strengthening of the role of radiation and local climate factors. There are no intensive invasions from the Arctic. The weather is largely determined by the activity of the Azores anticyclone, expressed in the spread of its spurs to the east. This process causes stable dry and warm, partly cloudy weather.

1 m m	9 71-75 Shelton Street Covent Garden London, United Kingdom, WC2H QIO	Sheet 11
Juru	€ info@juru.org	All sheets 57



In November the pre-winter begins. With further intensification of cyclonic activity and cold intrusions, winter comes.

Periodic disruption of the summer circulation begins at the end of August, when cyclonic activity intensifies and the frequency of northwestern and western cyclones increases. In October, more intense cold intrusions are observed in the rear of cyclones. In autumn, the spurs of the Azores anticyclone are destroyed, and the spurs of the Siberian anticyclone are increasingly spreading from the east. The speed of movement of western cyclones decreases as they approach the spurs of the continental anticyclone; Cloudy weather forms in the transition zone.

2.2. SOLAR RADIATION

The source of energy for physical processes occurring on the earth's surface and in the atmosphere is the radiant energy of the Sun. Its influx onto the earth's surface depends on the angle of inclination of the sun's rays, which at any given time is determined by the latitude of the area, the declination of the sun and the time of day, knowledge of the duration of daylight is required, which in turn is determined by the latitude of the area and the declination of the sun on a given day.

Solar radiation enters the earth's surface in the form of two streams: direct solar radiation S, emanating directly from the solar disk, and diffuse radiation D, emanating from the entire vault of heaven. The sum of these fluxes is called total radiation Q. At meteorological stations, direct solar radiation S arriving at a surface perpendicular to the sun's rays is measured.

The arrival of total radiation depends on the height of the sun, the length of the day, the transparency of the atmosphere, cloudiness and albedo of the underlying surface. The amount of solar radiation reaching the earth's surface depends on the latitude of the place, the height of the sun, cloudiness and transparency of the atmosphere.

In territory, the average duration of sunshine per year is 2244 hours, or 58% of the theoretically possible amount. The minimum duration of sunshine is observed in winter, in December - February (85-88 hours, or 34-35% of the possible).

JUCU Shelton Street Covent Garden London, United Kingdom, WC2H 9JQ Shelton Street Covent Garden London, United Kingdom, WC2H 9JQ	Sheet 12 All sheets 57
--	---------------------------

Juru



In Baku, the average annual solar radiation is 5564 MJ/m². At the same time, most of the total radiation from April to September is due to direct radiation, and in the period from October to March - to diffuse radiation.

Months	S	S'	D	Q	R
January	201	71	96	168	38
February	205	92	130	222	54
March	335	184	205	390	84
April	458	293	260	553	126
Мау	675	469	272	742	163
June	788	566	239	804	176
July	750	532	256	788	172
August	729	490	226	716	163
September	528	314	188	503	117
October	323	159	172	331	75
November	205	80	113	193	46
December	176	59	96	155	22
Annual	5373	3309	2253	5565	1236

Table 2.1: Monthly and annual amounts of solar radiation under average cloudy conditions (MJ/m²)

The radiation balance under cloudy conditions decreases compared to the radiation balance under clear skies, but to a lesser extent than direct and total radiation, since cloudiness also reduces the expenditure part of the radiation balance - effective radiation and reflected radiation.

When the solar disk is open, an increase in cloudiness can lead to a slight increase in the radiation balance compared to a cloudless sky.

Maximum values of the radiation balance can reach 411 MJ/m^2 in June and decrease to 38 MJ/m^2 in December.

	71 75 Shalton Street Covent Carden London United Kingdom WC2H 010	Sheet 13
Juru	₩ www.www.juru.org	All sheets 57

Juru



2.3. AIR TEMPERATURE REGIME

According to the recommendations of the World Meteorological Organization, the period from 1961 to 1991 was adopted for calculating the basic climate normal, and in recent years from 1991 to 2022. In this regard, it became necessary to revise the norms of the main climatic characteristics and draw up new climatic descriptions of the territory on the basis.

Table 2.2 below shows the ambient temperature indicators observed in the meteorological station of Bilasuvar in 1992-2022 years.

Months	The long-time annual average	Absolute maximum	The long-time annual maximum	Absolute minimum	The long-time annual minimum
January	4.4	23.5	17.0	-12.1	-3.9
February	5.3	26.6	19.4	-7.1	-2.9
March	8.7	36.5	22.9	-2.5	0.3
April	13.5	36.9	27.8	-1.6	3.5
May	19.7	39.2	33.0	1.6	8.4
June	24.9	40.6	36.6	0.0	14.1
July	27.3	43.3	38.3	2.2	16.3
August	27.1	43.1	38.5	1.9	16.1
September	22.5	39.7	34.6	2.2	12.2
October	16.5	34.2	29.3	0.7	6.5
November	10.2	32.1	22.4	-3.9	1.9
December	5.8	26.0	18.2	-6.8	-2.2
Annual	15.5	43.3	28.2	-12.1	5.9

Table 2.2: Long-term indicators of air temperature in Bilasuvar (for periods 1992-2022), °C

The main indicators of the temperature regime are the average monthly maximum and minimum ambient temperatures. According to the data analysis in the table in the territory the average annual air temperature is +15.5 °C, absolute minimum air temperature was -12.1 °C. the absolute maximum

71 75 Shalton Street Covent Corden London United Kingdom WC2H 010	Sheet 14
2 1-75 Shelton Street Covent Garden London, United Kingdom, WC2H SiQ	
() +44 207 859 4028, +44 207 691 9406	All sheets 57
www.www.juru.org	Thi blicets 57



JL



was +43.3 °C. The coldest month of the year is January with an average monthly ambient temperature of 4.4 °C. the warmest is July with an average monthly temperature of +27.3 °C.

Distribution parameters of extreme air temperature observed at Bilasuvar meteorological station are presented in the following table.

Danas	Minimum air temperature, °C			Maximum air temperature, °C			
капде	Years	Temperature	Probability density	Years	Temperature	Probability density	
1	2003	-2.5	0.018	1994	36.4	0.018	
2	2011	-2.6	0.0501	1992	37.0	0.0501	
3	2015	-2.6	0.0823	2003	37.0	0.0823	
4	2019	-2.6	0.1144	2013	37.0	0.1144	
5	2018	-2.8	0.1465	1993	37.3	0.1465	
6	2020	-2.9	0.1787	1995	38.0	0.1787	
7	2004	-3.3	0.2108	1996	38.0	0.2108	
8	2005	-3.4	0.2429	1997	38.0	0.2429	
9	1999	-3.5	0.2751	2012	38.6	0.2751	
10	2000	-3.6	0.3072	1998	38.7	0.3072	
11	2022	-4.1	0.3393	2005	38.8	0.3393	
12	2021	-4.3	0.3715	2008	38.8	0.3715	
13	2010	-4.6	0.4036	2020	38.8	0.4036	
14	1992	-4.7	0.4357	2002	39.0	0.4357	
15	2001	-4.8	0.4679	2004	39.0	0.4679	
16	2013	-4.8	0.5	2001	39.1	0.5	
17	1997	-4.9	0.5321	2007	39.2	0.5321	
18	2006	-4.9	0.5643	2009	39.2	0.5643	
19	2007	-5.2	0.5964	2010	39.3	0.5964	

Table 2.3: Distribution parameters of the maximum and minimum air temperature

	71 75 Sholton Street Covent Carden London United Kingdom WC2H 910	Sheet 15
Iru	€ info@juru.org	All sheets 57

Juru

COMBINED CAPACITY OF 835MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-BILASUVAR SOLAR PV



Denge	Minimum air temperature, °C			Maximum air temperature, °C			
Years Temperature Probability density		Years	Temperature	Probability density			
20	2017	-5.3	0.6285	2019	39.3	0.6285	
21	1995	-5.7	0.6607	1999	39.5	0.6607	
22	1996	-5.8	0.6928	2016	39.5	0.6928	
23	1998	-5.9	0.7249	2014	39.7	0.7249	
24	2012	-5.9	0.7571	2022	39.7	0.7571	
25	1993	-6.1	0.7892	2000	40.2	0.7892	
26	1994	-6.8	0.8213	2006	40.5	0.8213	
27	2002	-6.8	0.8535	2015	40.5	0.8535	
28	2014	-7.1	0.8856	2021	40.6	0.8856	
29	2008	-8.5	0.9177	2011	40.7	0.9177	
30	2016	-9.1	0.9499	2017	43.1	0.9499	
31	2009	-12.1	0.982	2018	43.3	0.982	

The calculated values of extreme maximum and minimum temperatures of various probability are determined by the distribution for a series of observation from 1992 to 2022 at the Bilasuvar meteorological station and Table 2.4 is presented.

Table 2.4: Calculated extreme air temperature according to Bilasuvar meteorological station, °C

Deturn period year		Extreme air tem		empe	eratures		
Return period, year	AEP, %	-IN(-IN(Pt))	Minimum		Maximum		
2	0.5	0.3665	-4.7		38.9		
5	0.8	1.4999	-6.7		40.3		
10	0.9	2.2504	-8.0	41.2			
20	0.95	2.9702	-9.2	42.1			
50	0.98	3.9019	-10.8	43.2			
100	0.99	4.6001	-12.0	44.1			
	71 75 Shalton Street Co	want Gardon London Linit	tod Kingdom WC2H QIO		Sheet 16		
Juru		207 859 4028, +44 207 691	.9406		All sheets 57		



2.4. REGIME OF RELATIVE HUMIDITY

The air humidity regime in Bilasuvar throughout the year is determined by the nature of circulation processes, expressed in changes in air masses. In winter, cold and relatively humid air masses come to the city; in summer, on the contrary, they are warm and dry. Humidity and air temperature are in a certain relationship: in areas of the city with high air temperatures, low humidity is observed, and in areas with low temperatures, high humidity is observed.

Table 2.5 below shows the ambient relative humidity indicators observed at the Bilasuvar meteorological station in 1992-2022 years.

Table 2.5: Air relative humidity indicators observed at the Bilasuvar meteorological station in period 1992-2022 years, %

Months	The long-time annual average	Absolute maximum	The long-time annual maximum	Absolute minimum	The long-time annual minimum
January	85.8	99.4	92.4 10.4		35.5
February	86.2	99.4	91.1	19.8	36.0
March	82.5	99.4	90.2	13.5	30.1
April	78.2	99.4	98.6	13.5	29.4
May	72.5	99.4	97.1	9.4	28.1
June	59.2	99.4	91.8	9.4	19.3
July	52.9	95.4	87.9	8.3	18.3
August	53.5	99.4	87.2	5.2	17.5
September	69.1	99.4	96.3	11.5	21.6
October	83.0	99.4	98.5	17.7	31.2
November	86.2	99.4	99.4	13.5	37.5
December	85.3	99.4	99.3	14.6	35.4
Year	74.5	99.4	96.2	5.2	28.3

The annual course of relative humidity, which characterizes the degree of ambient saturation with water vapor, is opposite to the annual course of water vapor elasticity and ambient temperature.

	2 71 75 Shelton Street Covent Corden London United Kingdom WC2U 010	Sheet 17
Juru	S+44 207 859 4028, +44 207 691 9406	All sheets 57
	🐨 www.www.juru.org 👁 info@juru.org	



From winter to summer, as the ambient temperature rises, the values of relative humidity gradually decrease. The strongest decrease is observed in April - May, which is explained by a significant increase in the influx of solar heat, intensification of transformation processes, and a sharp decrease in precipitation in May.

Table 2.6 below show the indicators of relative air humidity observed by terms at certain times of the day at the Bilasuvar meteorological station.

Table 2.6: Air relative humidity indicators observed by terms at certain times the Bilasuvar meteorological station in period 1992-2022 years, %

Months	21:00	00:00	03:00	06:00	09:00	12:00	15:00	18:00
January	85.5	86.6	86.5	83.5	76.5	75.0	82.6	86.1
February	85.8	87.4	87.5	84.0	76.0	74.6	81.8	87.6
March	84.3	87.0	86.6	79.8	72.0	68.9	76.2	85.8
April	81.0	84.9	83.9	73.2	65.7	63.9	71.4	83.4
May	75.9	83.1	82.0	66.3	58.6	55.7	62.7	79.6
June	63.9	74.1	71.4	52.1	45.1	43.7	49.4	69.8
July	54.4	64.7	61.5	43.5	37.2	37.3	42.7	59.9
August	57.3	65.5	63.8	46.8	39.8	39.8	46.6	62.0
September	72.8	78.9	77.7	63.7	54.7	52.5	62.5	76.8
October	84.6	88.2	88.1	80.2	69.6	68.3	78.7	86.9
November	86.5	88.2	87.5	82.4	73.2	73.1	83.5	88.0
December	85.2	86.3	85.3	81.9	73.6	73.2	82.1	86.1
Year	76.4	81.3	80.1	69.8	61.8	60.5	68.3	79.3

The average annual relative air humidity in the region was 74.5%, the maximum average monthly relative air humidity in the region is observed in December-January (86%), the minimum in June-July (52%).

100 B	271-75 Shelton Street Covent Garden London, United Kingdom, WC2H 910	Sheet 18
Juru	€ info@juru.org	All sheets 57



2.5. PRECIPITATION

Monthly and annual precipitation is given in millimeters, which measure the height of the water layer that has fallen to the surface of the earth.

The annual course of precipitation in the site is characterized by its predominance in the winterspring period, the maximum occurs in March (30.7 mm), the minimum in July - August (4.3-7.0 mm with virtually no precipitation). In the cold half of the year (November-March) there is 2 times more precipitation than in the warm half of the year. (April-October). The average annual precipitation is 297.9 mm.

Table 2.7 below shows the indicators of the amount of precipitation observed at the Bilasuvar meteorological stations between 1992 and 2022 years.

Table 2.7: Average monthly, absolute maximum, minimum precipitation the Bilasuvar meteorological station for each month period 1992-2022 years, mm.

Months	The long-time annual average	Absolute maximum	Absolute minimum
January	26.7	85.9	5.8
February	32.5	91.7	2.9
March	30.7	55.3	8.2
April	27.4	73.0	1.8
May	25.7	127.2	1.5
June	11.9	55.3	0
July	4.3	18.0	0
August	7.0	30.0	0
September	23.6	103.3	0.7
October	44.6	137.2	1.5
November	37.7	119.3	0.6
December	25.8	65.2	2.9

	71.75 Shalton Street Covent Corden London United Kingdom WC2U 010	Sheet 19
hier		
5010	Section 2017 859 4028, +44 207 691 9406	All sheets 57
	🗰 www.www.juru.org 🖄 info@juru.org	



2.6. ATMOSPHERE PRESSURE

Atmospheric pressure varies significantly throughout the year depending on the nature of atmospheric circulation and the time of year. Higher pressure is observed in the cold season due to the invasion of cold air from the north and east in the spurs and ridges of the Siberian anticyclone and air compaction as the temperature drops; lower pressure is observed in the warm half of the year due to the general warming of the atmosphere.

The average annual atmospheric pressure normalized to sea level at the Bilasuvar meteorological station is 1018.5 hPa. It has a minimum in summer and a maximum in winter. With the onset of a cold period, the pressure at the site increases. Its sharpest increase is observed in September and October, when the pressure difference between neighboring months reaches 2.5 hPa.

Table	2.11:	Average	monthly	and	observed	by	terms	at	certain	times	atmosph	eric	pressur	e in
Bilasu	ıvar fo	r each mo	onth and f	^f or th	e year and	d da	ite of a	ppe	arance	for per	iod 1992-	2022	2 years,	hPa

Months	The long-time annual average	21:00	00:00	03:00	06:00	09:00	12:00	15:00	18:00
January	1001.3	1000.7	1000.2	1000.1	1000.8	1001.3	1000.7	1001.2	1000.4
February	1000.6	1003.1	1001.6	1001.3	1003.2	1001.8	1001.1	1002.9	1002.9
March	1000.0	1000.2	999.7	999.6	1000.3	1000.0	999.4	999.7	1000.1
April	1000.8	1000.0	999.3	999.1	999.6	999.4	999.0	1000.2	999.8
May	1001.5	1001.9	1001.3	1001.3	1001.6	1001.5	1001.1	1001.1	1001.7
June	1000.9	1001.1	1000.7	1000.8	1001.0	1000.7	1000.4	1000.3	1001.0
July	1000.7	1001.0	1000.7	1000.8	1001.0	1003.0	1000.4	1000.3	1000.9
August	1002.0	1002.3	1001.9	1001.9	1002.1	1001.9	1001.5	1000.4	1002.2
September	1002.5	1003.8	1003.3	1003.2	1003.6	1003.3	1002.8	1001.9	1003.6
October	1005.3	1005.4	1004.8	1005.8	1005.3	1005.0	1003.3	1004.9	1005.1
November	1003.5	1003.3	1004.0	1003.9	1004.6	1004.0	1002.3	1000.6	1004.3
December	1003.2	1003.3	1003.0	1002.8	1003.5	1002.9	1002.3	1003.0	1003.2
Year	1001.9	1002.2	1001.7	1001.7	1002.2	1002.1	1001.2	1001.4	1002.1

📕71-75 Shelton Str	eet Covent Garden L	ondon, United	Kingdom, V	VC2H 9JQ
C	+44 207 859 4028, +	-44 207 691 94	106	

🐨 www.www.j<u>uru.org</u> 🖄 <u>info@juru.org</u> Sheet 20

Juru



3. HYDROLOGIC AND HYDRAULIC STUDIES

3.1. OBJECTIVES AND WORK FLOW

The objective of this study is to develop and evaluate the existing drainage patterns and flow rates for the runoff tributary to the Project. The hydrology will be the base used to determine the location of the natural watercourses upstream and within the project area and the amount of runoff that flows in the existing watercourses.

Taking account of the goals of the recommended project, the objectives of the hydrological and hydraulic studies are set as follows:

- ✓ The 100-year (1%AEP Annual Exceedance Probability), 50-year (2% AEP), 25-year (4% AEP) and 10-year (10% AEP) inundation limits will also be determined for the major watercourse that crosses the Project. The proposed design of the Project will then take into account the location of the existing drainage courses and the amount of flow, as well as the 25, 50 100-year flow width, depth, and the velocity. This study will also show the change in runoff rates and characteristics and the 25, 50, 100-year inundation limits due to the development of the Project;
- ✓ Flood modelling for different return periods and application of results on survey plan to establish the flood lines for different return periods for the Project site
- ✓ Identification of constraints limiting the use of spaces on banks
- ✓ Considering the need for flood mitigation and development considerations
- ✓ Flood management measures
- Application of hydraulic data of drainage lines crossing the road and the conceptual culvert design
- Assessing flood risk for extreme situations and giving recommendations on reducing risks, provide conclusions on mitigation measures;
- ✓ To recommend betterment of drainage system along the proposed alignment, where deterioration of present drainage conditions due to implementation of the project is predicted, if any.





3.2. SCOPE OF WORKS

Juru

Juru

The overall scope of the study includes a set of works to determine the risk of flooding of the future construction site.

Based on the above, the following tasks were defined as research objectives:

- A study should be conducted on the following topography data sets: Conduct a topography study using site measure data with spatial resolution of 0.1 to 0.5m, satellite based Digital Elevation Model (DEM and satellite imagery, which will give a better understanding of the terrain surface
- ✓ Have a general overview of the physical and hydraulic characteristics of the Waterways through the site;
- On-site review of waterways and delimitation of conditions of lows. Inspection of upstream and downstream of the study area. To identify the hydraulic constraints limiting the use of the spaces in the banks;
- ✓ Watershed based Hydrological model. Rainfall analysis shall be based on local standards Collection of relevant rainfall data (hourly, daily, yearly etc.) for the project site. Analyze the rainfall data and estimate maximum rainfall depth for 24 hours and for various short durations including duration of concentration (time of concentration) for 2-, 25-, 50- and 100-year return-period. The rainfall data and analysis shall be included in the report;
- ✓ Collect the details of historical flood data and its study. Analysis of runoff coefficient and manning's coefficient, time of concentration. Estimate the maximum rainfall intensities for various return periods & durations including concentration times and prepare Intensity-Duration-Frequency (IDF) curve. Analysis of rainfall hyetograph. Assessment of all probable source of flooding like flash floods, pluvial flooding, fluvial flooding, groundwater flooding;
- Study and evaluate whether providing storm water drainage is must or the risk can be mitigated by raising the structure above the HFL expected. In case there is run off intercepting the plant and drainage is required, whether there is embankment or peripheral drain to be provided. The height of embankment or section of peripheral drain to be evaluated along with tentative location on proposed plot plan;



- ✓ A soft copy of drawing showing the Flood level of 100-year (1%AEP), 50-year (2% AEP), 25year (4% AEP) and 10-year (10% AEP). Generation of micro streams within the project site. Watershed analysis should cover macro watershed-based runoff estimation. Flood risk assessment within the project site. Prepare flood inundation map indicating the flood levels, inundated area, flow direction and velocity in and around the plant area;
- Flood risk at the access of the plant areas. High flood level impact assessment at the drainage outlet points in project site area. Various types of remedial measures with drainage patterns and discharge points locations described with detailed feasibility for the site flooding;
- ✓ Development pre-project & post project hydraulic study, potential scour and recommendation for the drainage design on the proposed plot plan.

Based on the results of hydrometeorological surveys, this report was compiled. Report as a minimum should consist of the project location, project description, study objective, hydrology design criteria, peak rainfall intensity in mm/hr, maximum daily rainfall, runoff coefficient at drainage area, software used, pre-project water shed characteristics, pre- project hydrology, post project watershed characteristics, post project hydrology, pre-and post-project peak flow summary. It shall also consist of flood hazard meaning thereby the inundation limits, flood depth, flow velocity, post project effect, potential scour and project site mitigation. Pre-project drainage design, post project drainage design, recommendation and summary shall also be included in the report.

3.3. DESIGN PRINCIPLES AND STANDARDS

Juru

The adopted governing philosophy was to provide minimal disruption to the natural drainage system on the site while protecting the solar farms from erosion and accommodating the proposed master plan development. The objectives of the design were to:

- ✓ Protect the solar farm panels from submergence by flood waters;
- ✓ Protect the solar farm panels from erosion;
- ✓ Provide basic storm water management infrastructure for the master plan;
- ✓ Reduce flows from the development to pre-development conditions;
- ✓ Minimize intervention to the natural drainage of the site.





The main standard is to qualify the impact of rainwater on the design structure in a building site using ASCE 7 Minimum Design Loads for Buildings and Other Structures, BS 851188-1:2019+A1:2021 Flood resistance products - Building products and other local codes.

3.4. MAXIMUM RAINFALL INTENSITY AND DURATION WITH RETURN PERIODS

The rainfall data observed at the weather station were processed statistically. The Gumbel method Type-1 was used to study the laws of empirical distribution.

In probability theory and statistics, the Generalized Extreme Value Distribution Type-1 is used to model the maximum (or minimum) of a number of units. In probability theory, the Gumbel density function Type-1 used mainly in extreme value and duration analysis (also known as duration analysis or event history modeling). The Gumbel Distribution Type-1 is a special case of the generalized extreme value distribution (also known as the Hera-Tippett distribution). It is also known as the logarithmic distribution and the double exponential distribution (the term sometimes used interchangeably to refer to the Laplace distribution).

The Gumbel distribution function Type-1is mathematically expressed as follows:

$$G(x,\mu,\beta) = \frac{1}{\beta}e^{\frac{x-\mu}{\beta}}e^{-e^{\frac{x-\mu}{\beta}}}$$

where m is the location parameter and b is the scale parameter.

The value of the random variable X_T is associated with a given recurrence period T can be obtained from the following expression:

$$X_T = \bar{X} + K_T * S$$

where X is the mean value of observations (for example, the arithmetic means of the observations) and S is the standard deviation of the observations.

The frequency factor is associated with the recurrence period T, K_T (Factor Gumbel EV), is determined by the following expression:

$$K_T = -\frac{\sqrt{6}}{\pi} \left[0.5772 + Ln(Ln(\frac{T}{T-1})) \right]$$

This equation is used to calculate the frequency ratios associated with return cycles (2, 5, 10, 25, 50, 100 years).





The empirical distribution showed a trend towards logarithmic growth; the correlation ranged between 0.90 and 0.95. The purpose of the analysis was to study empirical distribution of the amount of the observed precipitation over 3, 6, 12 and 24-hour intervals.

Table 3.1 below shows the amount of rainfall observed at the Bilasuvar meteorological station in the period 1992-2021 years.

Table 3.1: 3-hour, 12-hour and daily maximum rainfall observed at the Bilasuvar meteorological station between 1992-2021 years

Range	Year	Maximum 3-hour rainfall, mm	Maximum 12-hour rainfall, mm	Maximum daily rainfall, mm
1	1992	17.6	37.4	52.8
2	1993	18.4	39.1	61.1
3	1994	19.6	41.6	54.1
4	1995	33.7	71.6	86.5
5	1996	17.2	36.5	54.0
6	1997	19.5	41.4	47.8
7	1998	25.2	53.5	75.0
8	1999	28.6	60.7	91.4
9	2000	18.4	39.1	73.7
10	2001	30.2	64.1	73.0
11	2002	24.0	51.0	76.2
12	2003	74.4	158.0	165.2
13	2004	22.0	46.7	78.4
14	2005	75.2	75.2	83.8
15	2006	22.8	48.4	163.8
16	2007	18.2	38.7	64.3
17	2008	21.7	46.1	61.7
18	2009	27.2	57.8	67.5
19	2010	24.0	51.0	59.9
20	2011	16.6	34.2	34.2
21	2012	12.2	25.9	43.2
22	2013	25.0	45.3	45.3

Juru

271-75 Shelton Street Covent Garden London, United Kingdom, WC2H 9JQ +44 207 859 4028, +44 207 691 9406

www.www.juru.org

Sheet 25 All sheets 57 Juru

COMBINED CAPACITY OF 835MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-BILASUVAR SOLAR PV



Range	Year	Maximum 3-hour rainfall, mm	Maximum 12-hour rainfall, mm	Maximum daily rainfall, mm
23	2014	31.4	66.7	91.0
24	2015	40.2	85.4	121.4
25	2016	23.2	49.3	85.3
26	2017	13.8	29.3	50.0
27	2018	25.7	54.6	65.9
28	2019	21.4	45.5	50.0
29	2020	17.8	37.8	43.4
30	2021	22.2	47.2	57.2

3.5. DATA COLLECTION

In hydrological modeling, digital relief model of the area, type of land cover, degree of infiltration of geological layers, structure of soil composition, amount of atmospheric precipitation, flow hydrographs of precipitation water were developed.

3.5.1. DIGITAL TERRAIN MODEL AND WATERSHED DEFINITIONS

The ALOS DEM model was used to create the DEM model based on region characteristics. https://www.eorc.jaxa.jp/ALOS/en/aw3d30/index.htm. The Global DEM model has a raster cell of 30*30 m (AW3D30) and has been corrected using ALASKA PALSAR data to improve its accuracy.

To improve accuracy of the DEM model, the area was corrected using topographic data. The 3D DEM model of the region was created using the ALOS Palsar DTM correction method. The resulting DEM model has a size of 12 meters in pixels, the vertical relief is corrected, and the accuracy is high.

The Complex Energy Index (CEI) was used as the basis for the proposed methodology for modeling the river network.

In the study, the analysis of the use of various forms of indices was carried out, on the basis of which the authors propose the general form of the index in the following form:

$$a = \delta * Q^m * \Delta z^n$$







where a is the index, Q is the flow rate, Δz is the local slope, δ , m and n are the parameters. Options for specifying the formula are the above-used areas of the water body A as a flow index:

$$Q_i \propto A_i$$

and also, the E relief energy index known in the literature:

$$E_i \varpropto A_i^{0.5} \ast \Delta z_i$$

Formulas in the form of a record used for calculations using the DEM, where i is the number of the raster cell in which the value of the corresponding index is calculated.

The raster coverage obtained as a result of processing the original DEM is used to calculate the derived data necessary for further calculations:

- flow directions;
- total drain;
- slope.

When working with several basins within the large DEM fragment, it is advisable to sequentially process the entire fragment to obtain raster coverages of Fill, Flow Direction, Flow Accumulation and Slope. After that, it is necessary to set closing gates for the simulated basins, select their water-collecting areas, which are then used as a mask (Environment Settings – Raster Analysis - Mask) to optimize the calculations by excluding the calculations of DEM points that lie outside the simulated basins. The river network structure is modeled by setting the CEI threshold value using the Raster Calculator tool of the SpatialAnalyst/MapAlgebra toolset using the Con function. As a result, the raster cells, the CEI values are selected with the limit which is greater than the specified one.

Discontinuities are removed by specifying the resulting raster as the weigh raster using the FlowAccumulation tool of the SpatialAnalyst/Hydrology toolset. In order to avoid the loss of the initial cells of the selected streams, the result obtained is summed up with the previously obtained raster of the river network with discontinuities by simple addition using the RasterCalculator tool of the SpatialAnalyst/MapAlgebra toolset.

	21 75 Shelton Street Covent Carden London, United Kingdom, WC2H 010	Sheet 27
1011		
	W +44 207 859 4028, +44 207 691 9406	All sheets 57
	🗰 <u>www.www.juru.org</u> \land <u>info@juru.org</u>	Thi sheets 57



The result of the summation is processed by the SetNull tool of the SpatialAnalyst/ Conditional toolset, replacing all cells that are not equal to zero, by one. As a result, we obtain a connected raster of the simulated river network, in which the primary water streams start from the points at which for the first time (along the flow line) the CEI value exceeded the specified one.

The resulting raster represents a linear waters stream network model to which the standard SpatialAnalyst/Hydrology toolset is consistently applied: StreamLink which identifies segments between two series connections, between a connection and a mouth, or between a connection and a source; StreamOrder which defines and assigns an order value to the identified raster segments of the water stream network; StreamtoFeature which converts a raster representing a linear water stream network to vector features.

Construction of watersheds network is implemented by means of a number of techniques that make it possible to implement the principle of their ordinal classification, coupled with the ordinal characteristics of the river network corresponding to them.

The algorithm for creating a raster model can be conditionally divided into two stages:

• obtaining the raster model of the river network, which stores in its attribute table both identifier of the private link of the channel network and identifier of the order;

• selection of raster cells lying on the border of each private water body.

Using the FlowDirection procedure, we process the initial DEM of the basin, and use the resulting raster of flow directions to obtain partial identified water bodies of a given order using the Watershed procedure and the river network raster obtained at the previous stage.

The result is a set of rasters corresponding to the number of the selected stream orders.

Each of them presents a network of boundaries of partial water bodies of the same order, formed by the boundary cells of the raster.

A 1:500 scale topographic map of the area was used to create digital models of the small-scale terrain. To develop a digital model of the terrain in raster format, the topo v raster function of the

	271 75 Chalten Street Covert Corden London United Kingdom WC2U 010	Sheet 28
Juru	S+44 207 859 4028, +44 207 691 9406	All sheets 57
	www.www.juru.org	All sheets 37



ArkGIS 16 program was used. The Topo to Raster tool is an interpolation method specifically designed for creating hydrologically correct digital elevation models (DEMs). It is based on the ANUDEM program developed by Michael Hutchinson.

The interpolation procedure was designed to take advantage of input data types that are publicly available and known characteristics of elevation surfaces. The method uses an iterative finite difference interpolation method. It is optimized to have the computational efficiency of local interpolation methods such as inverse distance weighted interpolation (IDW) without the loss of surface continuity of global interpolation methods such as Kriging and Spline. It is essentially a discretized planar spline method in which the roughness factor is modified so that the adjusted DEM can accommodate abrupt changes in the surface (such as gorges, mountain ridges, steep cliffs).

Digital models of detailed terrain were developed with a spatial resolution of 0.1 to 0.5 m.

The figure below shows a digital relief model of the construction object with a spatial resolution of 0.5 m. The territory lies between -19.5 -25.4 meters above sea level.

Care 10	71-75 Shelton Street Covent Garden London, United Kingdom, WC2H 910	Sheet 29
Juru	€ 1 / 5 Shekton Street Covent Gurden London, Onited Kingdoni, Wezh 55g € +44 207 859 4028, +44 207 691 9406 € <u>info@juru.org</u>	All sheets 57
HYDROMETEOROLOGICAL STUDY REPORT





Figure 3.1: Sub basins and drainage network system obtained from 30 m ALOS PALSAR data

HYDROMETEOROLOGICAL STUDY REPORT





Figure 3.2: Topographic survey DEM for model area





3.5.2. GEOLOGICAL STRUCTURES

From the geological point of view, the region is dominated by a complex consisting of alluvial and pre-alluvial deposits and marine deposits.

The area is covered with marine sedimentary rocks of the latest age.

Figure 3.3 below shows the geological map of Azerbaijan.



Figure 3.3: Geological map of the territory (source: www.azerbaijan.az)





3.5.3. LAND USE LAND COVER DATA

According to the type of land use, the studied area consists mainly of Grass. In some places, there is a bog landscape formed as a result of bogs.



Figure 3.4: Land use and land cover map Azerbaijan (source: www.azerbaijan.az)

Global land-cover datasets have been downloaded from source the Environmental Systems Research Institute (ESRI) Sentinel-2 10m Land Use/Land Cover Time Series data set https://www.arcgis.com/apps/instant/media/index.html?appid=fc92d38533d440078f17678ebc20 e8e2.

JUCU	treet Covent Garden London, United Kingdom, WC2H 9IO	271-75 Shelton S	
All sheets S	\mathbf{b} +44 207 859 4028, +44 207 691 9406All sheets \mathbf{w} \mathbf{w} \mathbf{w} \mathbf{w} \mathbf{w} \mathbf{w} \mathbf{w} \mathbf{w} \mathbf{w}		Jur

HYDROMETEOROLOGICAL STUDY REPORT





Figure 3.5: Land use and land cover map of the territory



3.5.4. FLOOD HYDROGRAPH DETERMINATION WITH INFILTRATION

In hydrological research, the direct rainfall method (DRM) is employed. DRM involves directly applying rainfall to the hydrodynamic surface-flow model. Advantages of this approach include the facilitation of cross catchment flows, a high definition of flow behavior in catchments, and the approach can replace the requirement for hydrological models within the 2D model domain. One of the most utilizable advantages of DRM method is to implement the infiltration of precipitation with relevant land cover and soil data for all meshes of basin.

For soil data, the Global Hydrological Soil Groups (HYSOGs250m) are used. This dataset represents hydrological soil group data set at a global scale with a spatial resolution of 250 m. According to this dataset, soil classes HSG-C: moderately high flow potential and HSG-C/D: undrained (<50% sand and 20-40% clay) dominate the region. Based on these data and relevant literature, suitable curves for different strata for the project area are presented. In addition, it should be noted that initial precipitation can also be determined for the infiltration layer.



Figure 3.6: USDA soil textural triangle



HEC-RAS allows the user to create an infiltration layer with the Deficit Constant, Soil Conversation Service (SCS) Curve Number, and Green and Broad methods. The SCS curve number estimates the amount of precipitation that becomes runoff and the amount of infiltration into the soil. It is very useful and provides dynamically infiltrated excess precipitation in different layers obtained with knowledge of soil and land cover. In this study, the SCS Curve Number method is used to estimate the water depth and hydrographs for the project areas. The method requires a combination of soil and land cover infiltration, which allows calculation of layer curves.

Flood modeling was done using HEC-RAS 2D software. Full 2D modeling approach is used, taking into account the topographical characteristics and hydrodynamic response of wind farms. The workspace was generated from a Digital Surface Model (DSM) with a spatial resolution of 0.5 m.

Surface roughness parameters are normally categorized into three groups according to its functionality. These groups are defined as amplitude parameters, spacing parameters, and hybrid parameters.

The Gauckler–Manning coefficient, often denoted as n, is an empirically derived coefficient, which is dependent on many factors, including surface roughness and sinuosity.

A variable Manning roughness factor is applied to account for the geological formation, surface features and land use of the site using the above satellite products. The coefficient of roughness (n) is selected based on the data available in the literature. Roughness parameters have ranges, especially in a complex region such as cropland, even the type of crops and vegetation height can change the roughness parameters. To avoid these effects, average safe values of the ranges for the roughness parameters are chosen.

Manning's equation is an empirical formula estimating the average velocity of a liquid flowing in a conduit that does not completely enclose the liquid, open channel flow. However, this equation is also used for calculation of flow variables in case of flow in partially full conduits, as they also possess a free surface like that of open channel flow. All flow in so-called open channels is driven by gravity.

	71 75 Shaltan Street Covent Cardon London United Kingdom WC2H 010	Sheet 36
Juru	↓44 207 859 4028, +44 207 691 9406 www.www.juru.org ♠ info@juru.org	All sheets 57



3.5.5. RAINFALL INTENSITY-DURATION-FREQUENCY DEFINITION

The rainfall intensity duration frequency (IDF) curves are graphical representations of the probability that a given average rainfall intensity will occur within a given period of time.

Providing mathematical relationship between the rainfall intensity, the duration, and the return period (or equivalent to the annual frequency of exceedance), the IDF curves allow for the estimation of the return period of an observed rainfall event or conversely of the rainfall intensity corresponding to a given return period. The deriving procedure of IDF curves involves utilization of long-term historical rainfall observations.

Tables 3.2, 3.3 and 3.4 below show the distribution parameters of rainfall observed at the Bilasuvar meteorological station for 3 hours, 12 hours and 24 hours.

Range	Year	Maximum 3-hour rainfall, mm	P _{Pr}	-ln(P _{Pr})	-ln(-ln(P _{Pr}))
1	2012	12.2	0.0186	3.9850	-1.3825
2	2017	13.8	0.0518	2.9605	-1.0854
3	2011	16.6	0.0850	2.4652	-0.9023
4	1996	17.2	0.1182	2.1354	-0.7587
5	1992	17.6	0.1514	1.8879	-0.6354
6	2020	17.8	0.1846	1.6896	-0.5245
7	2007	18.2	0.2178	1.5242	-0.4215
8	1993	18.4	0.2510	1.3823	-0.3238
9	2000	18.4	0.2842	1.2581	-0.2296
10	1997	19.5	0.3174	1.1476	-0.1377
11	1994	19.6	0.3506	1.0481	-0.0470
12	2019	21.4	0.3838	0.9576	0.0433
13	2008	21.7	0.4170	0.8747	0.1339
14	2004	22.0	0.4502	0.7981	0.2256
15	2021	22.2	0.4834	0.7269	0.3190
16	2006	22.8	0.5166	0.6605	0.4148
17	2016	23.2	0.5498	0.5982	0.5138

Table 3.2: Distribution parameters of the maximum 3 hour and daily Rainfall for mm.

21.75 Shelton Street Covent Carden Lenden United Kingdom WC2U.00	Sheet 37
21-75 Shelton Street Covent Garden London, Onited Kingdom, WC2H 9JQ	
S +44 207 859 4028, +44 207 691 9406	All sheets 57
www.www.juru.org 🗠 info@juru.org	THI SHOELS 57

COMBINED CAPACITY OF 835MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-BILASUVAR SOLAR PV



Range	Year	Maximum 3-hour rainfall, mm	P _{Pr}	-ln(P _{Pr})	-ln(-ln(P _{Pr}))
18	2002	24.0	0.5830	0.5396	0.6170
19	2010	24.0	0.6162	0.4842	0.7253
20	2013	25.0	0.6494	0.4317	0.8400
21	1998	25.2	0.6826	0.3818	0.9627
22	2018	25.7	0.7158	0.3343	1.0956
23	2009	27.2	0.7490	0.2890	1.2413
24	1999	28.6	0.7822	0.2456	1.4039
25	2001	30.2	0.8154	0.2041	1.5893
26	2014	31.4	0.8486	0.1642	1.8069
27	1995	33.7	0.8818	0.1258	2.0732
28	2015	40.2	0.9150	0.0888	2.4211
29	2003	74.4	0.9482	0.0532	2.9340
30	2005	75.2	0.9814	0.0188	3.9756

Table 3.3: Distribution parameters of the maximum 12 hour and daily Rainfall for mm.

Range	Year	Maximum 12-hour rainfall, mm	P _{Pr}	-ln(P _{Pr})	$-\ln(-\ln(P_{Pr}))$
1	2012	25.9	0.0186	3.9850	-1.3825
2	2017	29.3	0.0518	2.9605	-1.0854
3	2011	34.2	0.0850	2.4652	-0.9023
4	1996	36.5	0.1182	2.1354	-0.7587
5	1992	37.4	0.1514	1.8879	-0.6354
6	2020	37.8	0.1846	1.6896	-0.5245
7	2007	38.7	0.2178	1.5242	-0.4215
8	1993	39.1	0.2510	1.3823	-0.3238
9	2000	39.1	0.2842	1.2581	-0.2296
10	1997	41.4	0.3174	1.1476	-0.1377
11	1994	41.6	0.3506	1.0481	-0.0470
12	2013	45.3	0.3838	0.9576	0.0433
13	2019	45.5	0.4170	0.8747	0.1339
14	2008	46.1	0.4502	0.7981	0.2256
15	2004	46.7	0.4834	0.7269	0.3190
16	2021	47.2	0.5166	0.6605	0.4148
		9 71 75 Shalton Streat Covent C	ardan London United Ki	nadom WC2H 010	Sheet 38
Juci	1			nguun, wczn sjų	
0010		G+44 207 859			All sheets 57
	www.www.juru.org				

COMBINED CAPACITY OF 835MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-BILASUVAR SOLAR PV



Range	Year	Maximum 12-hour rainfall, mm	P _{Pr}	-ln(P _{Pr})	-ln(-ln(P _{Pr}))
17	2006	48.4	0.5498	0.5982	0.5138
18	2016	49.3	0.5830	0.5396	0.6170
19	2002	51.0	0.6162	0.4842	0.7253
20	2010	51.0	0.6494	0.4317	0.8400
21	1998	53.5	0.6826	0.3818	0.9627
22	2018	54.6	0.7158	0.3343	1.0956
23	2009	57.8	0.7490	0.2890	1.2413
24	1999	60.7	0.7822	0.2456	1.4039
25	2001	64.1	0.8154	0.2041	1.5893
26	2014	66.7	0.8486	0.1642	1.8069
27	1995	71.6	0.8818	0.1258	2.0732
28	2005	75.2	0.9150	0.0888	2.4211
29	2015	85.4	0.9482	0.0532	2.9340
30	2003	158.0	0.9814	0.0188	3.9756

Table 3.3: Distribution parameters of the maximum 24 hour and daily Rainfall for mm.

Range	Year	Maximum daily rainfall, mm	P _{Pr}	-ln(P _{Pr})	-ln(-ln(P _{Pr}))
1	2011	34.2	0.0186	3.9850	-1.3825
2	2012	43.2	0.0518	2.9605	-1.0854
3	2020	43.4	0.0850	2.4652	-0.9023
4	2013	45.3	0.1182	2.1354	-0.7587
5	1997	47.8	0.1514	1.8879	-0.6354
6	2019	50.0	0.1846	1.6896	-0.5245
7	2017	50.0	0.2178	1.5242	-0.4215
8	1992	52.8	0.2510	1.3823	-0.3238
9	1996	54.0	0.2842	1.2581	-0.2296
10	1994	54.1	0.3174	1.1476	-0.1377
11	2021	57.2	0.3506	1.0481	-0.0470
12	2010	59.9	0.3838	0.9576	0.0433
13	1993	61.1	0.4170	0.8747	0.1339
14	2008	61.7	0.4502	0.7981	0.2256

	2 71 75 Shaltan Street Covent Corden Lenden, United Kingdom, WC2U 010	Sheet 39
Juru	₩www.www.juru.org	All sheets 57

COMBINED CAPACITY OF 835MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-BILASUVAR SOLAR PV



Range	Year	Maximum daily rainfall, mm	P _{Pr}	-ln(P _{Pr})	-ln(-ln(P _{Pr}))
15	2007	64.3	0.4834	0.7269	0.3190
16	2018	65.9	0.5166	0.6605	0.4148
17	2009	67.5	0.5498	0.5982	0.5138
18	2001	73.0	0.5830	0.5396	0.6170
19	2000	73.7	0.6162	0.4842	0.7253
20	1998	75.0	0.6494	0.4317	0.8400
21	2002	76.2	0.6826	0.3818	0.9627
22	2004	78.4	0.7158	0.3343	1.0956
23	2005	83.8	0.7490	0.2890	1.2413
24	2016	85.3	0.7822	0.2456	1.4039
25	1995	86.5	0.8154	0.2041	1.5893
26	2014	91.0	0.8486	0.1642	1.8069
27	1999	91.4	0.8818	0.1258	2.0732
28	2015	121.4	0.9150	0.0888	2.4211
29	2006	163.8	0.9482	0.0532	2.9340
30	2003	165.2	0.9814	0.0188	3.9756

The data in the above table was analyzed according to the laws of distribution and the distribution probabilities were determined. The EVA analysis was carried out assuming a Gumbel distribution with a method of moments (MoM) estimator.

Due to the unavailability of observed rainfall data for time intervals smaller than 3 hours, an extrapolation adjustment was made. As a result of this extrapolation adjustment, it was possible to determine the values of precipitation amount up to the amount that can fall in an interval of up to 30 minutes.

The distribution of actual 10-minute maximum rainfall over time was calculated using the coefficients given in SN-63-76, "Guidelines for the Analysis of Storm Water Runoff from Small Reservoirs".

Figure 3.2 below shows a plot of observed precipitation versus logarithmic distribution parameters.

	71 75 Shalton Street Covent Carden London United Kingdom WC2H 010	Sheet 40
Juru	₩ www.www.juru.org	All sheets 57







	2 71 75 Shalton Street Covent Corden London United Vingdom WC2H 010	Sheet 41
Juru	www.www.juru.org 🖄 info@juru.org	All sheets 57



Return period,		E)/ Factor	Ra	Rainfall depth in mm.		
year	AEP, %	EVFACIO	3 hour	12 hour	24 hour	
2	0.5	0.3665	24.2	49.2	67.8	
5	0.8	1.4999	36.0	69.2	95.1	
10	0.9	2.2504	43.8	82.5	113.2	
20	0.95	2.9702	51.3	95.3	130.5	
50	0.98	3.9019	61.0	111.8	152.9	
100	0.99	4.6001	68.3	124.2	169.7	

Table 3.4: The Rainfall Depth Duration Frequency for Bilasuvar meteorological station, mm

Rainfall analysis was performed to generate intensity duration frequency (IDF) and depth duration frequency (DDF) curves needed to estimate rainfall depth for different event durations and frequencies. Determining design phenomena for further analysis, such as surface flow rates, attenuation volume requirements, and designing drainage components requires information from the IDF curve.

The Intensity Duration Frequency values of the final precipitation are shown in Table 3.5

Duration hour	Return Period, years					
Duration, nour	2	5	10	25	50	100
0.5	23.4	26.9	31.6	36.3	40.9	46.0
1	18.0	20.7	24.3	27.9	31.5	35.4
2	10.9	13.5	15.8	18.2	20.5	23.1
3	8.1	12.0	14.6	17.1	20.3	22.8
12	4.1	5.8	6.9	7.9	9.3	10.3
24	2.8	4.0	4.7	5.4	6.4	7.1

Table 3.5: Intensity Duration Frequency, Rainfall intensity for mm/hour

Juru	271-75 Shelton Street Covent Garden London, United Kingdom, WC2H 9JQ +44 207 859 4028, +44 207 691 9406	Sheet 42 All sheets 57
	www.www.juru.org	



4. FLOOD HYDRAULIC MODEL RESULTS

The software used to perform the hydraulic simulation has been HEC-RAS in version 6.1. HEC-RAS is a numerical model of simulation of turbulent flow in free flow and non-permanent regime conditions, and of environmental processes in river hydraulics. The hydrodynamic module, which is the basis of HEC-RAS, solves the two-dimensional shallow water averaged in depth equations.

Flood maps of the area were developed based on the results of hydraulic modeling. Flood levels are assessed using the following flood index criteria. Flood risk is identified by criteria in the table below.

Flood Hazard Index	Flood depth, m	Flood Velocity, m/s	Classification
H1	<0.5	<0.2	Very low
H2	0.5-1.0	0.2-0.5	Low
Н3	1.0-2.0	0.5-1.0	Medium
H4	2.0-5.0	1.0-3.0	High
H5	>5.0	>3.0	Extreme

Table 4.1: Flood Hazard Index classes

Flood Hazard Index H1 does not cause inconvenience to people's lives, transportation, and detailed operation of buildings and power lines. The depth of the flood water is up to 0.5 meters and the speed is up to 0.2 m/sec.

Flood Hazard Index H2 causes inconvenience to people's lives, transport supply and detailed operation of buildings and power lines. In this case, the depth of the flood water is up to 1.0 meters and the speed is up to 0.5 m/sec.

Flood Hazard Index H3 prevents people's lives, transportation, and the detailed operation of buildings and power lines. In this case, the depth of the flood water is up to 2.0 meters and the speed is up to 1.0 m/sec.

Flood Hazard Index H4 and H5 pose a threat to human life, the transport system is completely disrupted, and buildings and structures are destroyed.

1 m 1	71-75 Shelton Street Covent Garden London, United Kingdom, WC2H 910	Sheet 43
Juru	€ 1-75 Shelton Street Covent Garden London, onited Kingdom, we211 550 € +44 207 859 4028, +44 207 691 9406 € <u>info@juru.org</u>	All sheets 57

HYDROMETEOROLOGICAL STUDY REPORT





Figure 4.1: Modeling results 10% AEP Flood Depth Map (Return period for 10 years)







Figure 4.2: Modeling results 5% AEP Flood Depth Map (Return period for 20 years)

	71 75 Shalton Streat Covent Cardon London United Kingdom WC2H 010	Sheet 45
Juru	€ www.www.juru.org Sinfo@juru.org	All sheets 57







Figure 4.2: Modeling results 2% AEP Flood Depth Map (Return period for 50 years)

	71 75 Shalton Street Covert Corden London United Kingdom WC2U 010	Sheet 46
Juru	₩www.www.juru.org	All sheets 57







Figure 4.3: Modeling results 1% AEP Flood Depth Map (Return period for 100 years)

	71 75 Shalton Streat Covent Carden London United Vingdom WC2H 010	Sheet 47
Juru	₩ www.www.juru.org	All sheets 57







Figure 4.4: Modeling results 10% AEP Flood Velocity Map (Return period for 10 years)

	21 75 Shelton Street Covent Carden Lenden United Kingdom WC2U 010	Sheet 48
Juru	₩ www.www.juru.org	All sheets 57







Figure 4.6: Modeling results 5% AEP Flood Velocity Map (Return period for 20 years)

	21 75 Shelton Street Covent Carden London United Kingdom WC2H 010	Sheet 49
Juru	₩ www.www.juru.org	All sheets 57







Figure 4.7: Modeling results 2% AEP Flood Velocity Map (Return period for 50 years)

	21 75 Shalton Street Covent Carden London United Kingdom WC2H 010	Sheet 50
Juru	₩ www.www.juru.org	All sheets 57







Figure 4.8: Modeling results 1% AEP Flood Velocity Map (Return period for 100 years)

	21 75 Shelton Street Covent Carden London United Kingdom M(C)U 010	Sheet 51
Juru	₩ www.www.juru.org	All sheets 57



5. FLOOD MITIGATION

The practice of taking actions or measures to control or limit flood risk by reducing vulnerability is commonly referred to as flood mitigation.

The studied area is located in the flood zone, which can occur as a result of the coast and rainfall. Document FEMA 55: Coastal Construction Manual provides extensive instructions on how to determine site-specific loads regarding coastal flood hazards. Additionally, American Society of Engineers (ASCE) 7-98 Minimum Design Loads for Buildings and Other Structures is an accepted reference to determine other loads, such as dead and live loads, to be used in combination with coastal flood loads to determine structural capacities of building components.

General Design of structures within fl ood hazard areas shall be governed by the loading provisions of ASCE 7 Minimum Design Loads for Buildings and Other Structures (ASCE/SEI 2010).

Flood mitigation measures for construction structures are recommended:

- According to the requirements of ASCE 24-14 regulatory document Top of lowest floor must be at, or above, Base Flood Elevation; electrical heating, ventilation, plumbing, and air conditioning equipment and other service facilities (including ductwork) must be designed and or located so as to prevent water from entering or accumulating within the components during flooding. Structural fill shall not be used unless design and construction of the structural fill accounts for consolidation of the underlying soil under the weight of the fill and the structure, differential settlement due to variations in fill composition and characteristics, and slope stability and erosion control during conditions of the design flood;
- ✓ Structures and fill shall not be constructed or placed in fl oodways unless it is demonstrated that those structures and fill will not increase the flood level during occurrence of the base flood discharge, and reduce the conveyance of the floodway;
- ✓ Land leveling does not reduce the risk of coastal flooding, coastal flood prevention measures increase the cost of the project. Taking into account the above, it is desirable that the height of the feet of the solar panels fixed to the ground should be 0.3 meters higher than the height of the flood in relation to the levelled terrian during the hundred-year return period;



- ✓ Structures and fill shall not be constructed or placed unless it has been demonstrated that the cumulative effect of proposed structures and fill, combined withal other existing and anticipated development, will not increase the base flood elevation more than 0.3 meter;
- ✓ Ingredients of concrete, including admixtures and reinforcing steel, quality of concrete, and the design and construction thereof shall comply with ACI 318 Building Code Requirements for Structural Concrete and Commentary (ACI 2014) with special consideration for requirements concerning durability, including protection from chlorides and sulfates found in a saltwater environment;
- ✓ It is necessary to build drainage networks based on the natural slope in order to remove the water collected during the rain. Drainage lines will be determined by the designer after final planning. According to the results of hydrological analysis, it is recommended to build open drainage in the area.
- ✓ New construction and substantial improvements shall not be constructed at the apex of an alluvial fan, in the fan's meandering flow paths, or in areas of the fan that have characteristics and evidence that the natural processes that form alluvial fans are active on the fan 's surface, including braided channels, erratic flow paths, and sediment transport. Construction in other areas of the alluvial fan shall meet the following requirements: The elevation of the lowest floor shall be a minimum of 0.3 meter above the highest adjacent grade, or higher, if required on a community's flood hazard map; Foundations shall be designed and constructed to resist scour caused by the actual flow velocity but not less than 2 m/s. Determination of actual flow velocities shall be based on a review of a community 's flood hazard map and flood hazard study or on hydraulic calculations; and Design and construction shall resist all load combinations specified in the following: Flood loads shall be combined with other loads as specified in ASCE 7 Minimum Design Loads for Buildings and Other Structures (ASCE/SEI 2010), either by using the allowable stress design method load combinations or by using the strength design method load combinations.

6. FLOOD MITIGATION FOR SOLAR POWER STATION CONSTRUCTION AREA

General Design of structures within flood hazard areas shall be governed by the loading provisions of ASCE 7 Minimum Design Loads for Buildings and Other Structures (ASCE/SEI 2010).

	271 75 Chalten Street Covert Carden Lenden United Kingdom WC211 010	Sheet 53
Juru	www.www.juru.org ☆ info@juru.org	All sheets 57



According to the ASCE 24-14 normative document, the studied area is classified as Coastal 0 Zone, Low Hazard Area. The planned construction will be included in the 3rd category according to the type of Use or Occupancy of Buildings and Structures.

Minimum Elevation of Wet Floodproofing: According to the ASCE 24-14 normative document, Solar arrays should be installed on elevated platforms at least 0.3 meters above the highest flood level recorded in the region.

Mitigating flood risks for a solar power plant construction site involves a combination of careful planning, engineering solutions, and operational strategies.

Use permeable materials for roads and pathways within the site to reduce surface runoff.

It is desirable to implement a weather monitoring system to provide early warnings of heavy rainfall or possible flooding. Construction activities should be planned to avoid periods of high flood risk during the rainy season.

Reservoirs can be created to temporarily store excess rainwater, and a plan can be developed to gradually return it to natural watercourses once the risk of flooding has subsided.

It is desirable to develop an integrated drainage network that includes underground pipes and open channels for effective water flow management.

By implementing these measures, the solar power plant can be better protected from flooding, ensuring both the safety of the infrastructure and the uninterrupted production of renewable energy.

7. RECOMMENDATIONS FOR CONSTRUCTION STRUCTURE

Structural steel exposed to direct contact with saltwater, salt spray, or other corrosive agents known to be present shall be hot-dipped galvanized after fabrication. Secondary components such as angles, bars, straps, and anchoring devices shall be stainless steel or hot-dipped galvanized after fabrication in accordance with the following:

Sec. 10	71-75 Shelton Street Covent Garden London, United Kingdom, WC2H QIO	Sheet 54
Juru	€ 1-75 Sherton Street Covent Garden London, Onited Kingdom, WC2H 55Q € +44 207 859 4028, +44 207 691 9406 € info@juru.org	All sheets 57





Metal Connectors and Fasteners Metal plates, connectors, screws, bolts, nails, and other fasteners exposed to direct contact by floodwater, precipitation, or wind-driven water shall be stainless steel or equivalent corrosion resistant material, or hot-dip galvanized in accordance with ASTM A123/A123M Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products (ASTM 2012d), ASTM A153/A153M Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware (ASTM 2009), ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process (ASTM 2011a), or ASTM A924/A924M Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process (ASTM 2010a).

Structural Steel pipe piles shall conform to ASTM A252/252M Standard Specification for Welded and Seamless Steel Pipe Piles (ASTM 2010b). Steel H piles and steel sheet piling shall conform to ASTM A572/A572M Standard Specification for High-Strength Low Alloy Columbium-Vanadium Structural Steel (ASTM 2012a) or ASTM A690/A690M Standard Specification for High-Strength Low-Alloy Nickel, Copper, Phosphorus Steel H-Piles and Sheet Piling with Atmospheric Corrosion Resistance for Use in Marine Environments (ASTM 2012b). Rolled steel shapes other than H piles shall conform to ASTM A36/A36M Standard Specification for Carbon Structural Steel (ASTM 2008a), ASTM A572/A572M Standard Specification for High-Strength Low-Alloy Columbium-Vanadium Structural Steel (ASTM 2012a), and ASTM A992/A992M Standard Specification for Structural Steel Shape s (ASTM 2011b). Cast steel shoes, where provided, shall conform to ASTM A148/A148M Standard Specification for Steel Castings, High Strength, for Structural Purposes (ASTM 2008b).



8. CONCLUSION

These engineering and meteorological surveys were carried out in connection with the upcoming development of design documentation for the facility: **«COMBINED CAPACITY OF 445 MWAC SOLAR PV POWER PLANTS IN AZERBAIJAN-CONSTRUCTION BILASUVAR SOLAR PV PROJECT IN THE REPUBLIC OF AZERBAIJAN**»

Flood mitigation measures for construction structures are recommended:

- ✓ According to the requirements of ASCE 24-14 regulatory document Top of lowest floor must be at, or above, Base Flood Elevation; electrical heating, ventilation, plumbing, and air conditioning equipment and other service facilities (including ductwork) must be designed and or located so as to prevent water from entering or accumulating within the components during flooding. Structural fill shall not be used unless design and construction of the structural fill accounts for consolidation of the underlying soil under the weight of the fill and the structure, differential settlement due to variations in fill composition and characteristics, and slope stability and erosion control during conditions of the design flood;
- ✓ Structures and fill shall not be constructed or placed in fl oodways unless it is demonstrated that those structures and fill will not increase the flood level during occurrence of the base flood discharge, and reduce the conveyance of the floodway;
- ✓ Land leveling does not reduce the risk of coastal flooding, coastal flood prevention measures increase the cost of the project. Taking into account the above, it is desirable that the height of the feet of the solar panels fixed to the ground should be 0.3 meters higher than the height of the flood in relation to the levelled terrian during the hundred-year return period;
- ✓ Structures and fill shall not be constructed or placed unless it has been demonstrated that the cumulative effect of proposed structures and fill, combined withal other existing and anticipated development, will not increase the base flood elevation more than 0.3 meter;
- Designs for Coastal High Hazard Areas and Coastal Zones shall account for local scour and erosion and shall be designed to resist loads from the following: Waves breaking against the bracing, side of the structure, and underside of the structure, Drag, inertia, and other wave-induced forces acting on structural members supporting elevated structures, Uplift forces from breaking waves



striking the undersides of structures, and Wave runup forces including those deflected by the structure;

- ✓ In the coastal flood zone, it is recommended to secure the foundations or supports of solar panels and other structures to the ground. These measures must withstand the hydrostatic pressure of the sea wave;
- ✓ Ingredients of concrete, including admixtures and reinforcing steel, quality of concrete, and the design and construction thereof shall comply with ACI 318 Building Code Requirements for Structural Concrete and Commentary (ACI 2014) with special consideration for requirements concerning durability, including protection from chlorides and sulfates found in a saltwater environment;
- ✓ It is necessary to build drainage networks based on the natural slope in order to remove the water collected during the rain. Drainage lines will be determined by the designer after final planning. According to the results of hydrological analysis, it is recommended to build open drainage in the area. The approximate direction of drainage is chosen perpendicular to the Kura River;
- ✓ New construction and substantial improvements shall not be constructed at the apex of an alluvial fan, in the fan's meandering flow paths, or in areas of the fan that have characteristics and evidence that the natural processes that form alluvial fans are active on the fan 's surface, including braided channels, erratic flow paths, and sediment transport. Construction in other areas of the alluvial fan shall meet the following requirements: The elevation of the lowest floor shall be a minimum of 0.3 meter above the highest adjacent grade, or higher, if required on a community's flood hazard map; Foundations shall be designed and constructed to resist scour caused by the actual flow velocity but not less than 2 m/s. Determination of actual flow velocities shall be based on a review of a community 's flood hazard map and flood hazard study or on hydraulic calculations; and Design and construction shall resist all load combinations specified in the following: Flood loads shall be combined with other loads as specified in ASCE 7 Minimum Design Loads for Buildings and Other Structures (ASCE/SEI 2010), either by using the allowable stress design method load combinations or by using the strength design method load combinations.

